

Triennial UST Spill Bucket Integrity Testing (Hydrostatic/Vacuum Test)

- The primary containment and interstitial space of the spill bucket shall be tested in accordance with the manufacturer's written guidelines or PEI/RP1200 "Recommended Practices for the Testing and Verification of Spill, Overfill, Leak Detection and Secondary Containment Equipment at UST Facilities."
- The primary and secondary walls are both considered to be tested at the same time if vacuum is used to test the interstice.

UST FACILITY						
Owner / Operator Name F		Facility Name		Facility ID#:	Facility ID#:	
Facility Street Address F		acility City		County		
TESTING CONTRACTOR INFORMATION						
Company Name		Phone		E-mail Address		
I certify, under penalty of law, that the testing data provided on this form documents the UST system equipment was tested in accordance with the manufacturer's guidelines and the applicable national industry standards listed in 9VAC25-580-82.						
Print Name of person conducting test Signature of person conducting test Test Date						
Identify Spill Bucket (By Tank Number, Stored Product, etc.)	Tank #					
Tank Size						
Product						
Indicate units for all measuremen	nts					
Bucket Manufacturer/Model						
Bucket Depth						
Construction	□ SW □ DW					
Bucket Installation Type	☐ Direct Bury ☐ Direct Bury w/Liner ☐ Containment sump	☐ Direct Bury ☐ Direct Bury w/Liner ☐ Containment sump	☐ Direct Bury ☐ Direct Bury w/Liner ☐ Containment sump	☐ Direct Bury ☐ Direct Bury w/Liner ☐ Containment sump	☐ Direct Bury ☐ Direct Bury w/Liner ☐ Containment sump	
Test Type	☐ Hydrostatic☐ Vacuum					
Liquid and debris removed from spill bucket?	☐ Yes ☐ No					
Visual inspection (No cracks, loose parts or separation of the bucket from fill pipe.)	☐ Pass ☐ Fail					
Tank riser cap included in test?	☐ Yes ☐ No ☐ N/A	☐ Yes ☐ No ☐ N/A	☐ Yes ☐ No ☐ N/A	☐ Yes ☐ No ☐ N/A	☐ Yes ☐ No ☐ N/A	
Drain valve included in test?	☐ Yes ☐ No ☐ N/A	☐ Yes ☐ No ☐ N/A	☐ Yes ☐ No ☐ N/A	☐ Yes ☐ No ☐ N/A	☐ Yes ☐ No ☐ N/A	
Wait time between applying water and start of test (if applicable)						
Primary Section Test Hydi	rostatic: Water level mu	st be within 1.5 inches	of top of bucket	Vacuum: Apply vacu	ium of 30 inches WC	
Begin I End Test Time	I	I	I	I	I	
Begin I End Reading	I	1	I	I	I	
Secondary Interstice Test Vacuum: Apply vacuum of 15 inches WC Gauge range (with units):						
Begin I End Test Time	I	I	I	I	I	
Begin I End Reading	I	I	I	I	I	
Pass/fail criteria: Must pass visual inspection. Pass if: Hydrostatic: Water level drop of less than 1/8 inch in 1 hour; Vacuum single-walled only: Maintain at least 26 inches water column for 1 minute; Vacuum double-walled: Maintain at least 12 inches water column for 1 minute						
Test Results	☐ Pass ☐ Fail					
Comments — (include information on repairs made prior to testing, and recommended follow-up for failed tests)						
Date next Spill Bucket integrity test due (required every 3 years)						
VIDCINIA DEDARTMENT OF ENVIDONMENTAL OHALITY 1111 E MAINLET SHITE 1400 DICHMOND VA 22210						