



Commonwealth of Virginia

VIRGINIA DEPARTMENT OF ENVIRONMENTAL QUALITY

1111 E. Main Street, Suite 1400, Richmond, Virginia 23219

P.O. Box 1105, Richmond, Virginia 23218

(800) 592-5482

www.deq.virginia.gov

Travis A. Voyles
Secretary of Natural and Historic Resources

Michael S. Rolband, PE, PWD, PWS Emeritus
Director
(804) 698-4020

January 4, 2024

Owner Address:	Other Address:
Mr. Harivadan Patel - Registered Agent c/o Om shree Incorporated 1010 Little Apple Dr. Thaxton, VA, 24174 - 0000	Physical Store Address: Sedalia Country Store 11394 Big Island Highway Big Island, VA 24525
Operator Address:	Other Address:
Mr. Pradeep Katwal 11394 Big Island Highway Big Island, VA 24525	

**PROPOSED CONSENT ORDER AND
NOTICE OF INFORMAL FACT FINDING PROCEEDING**

RE:

Responsible Party(ies)	Om shree Incorporated - Mr. Pradeep Katwal
Facility Name	Sedalia Country Store
Facility No.	2041607

Dear Sir/Madam:

The Virginia Department of Environmental Quality ("DEQ") issued Notice(s) of Violation (the "NOV(s)") on the following date(s) to the Responsible Party(ies) identified above for alleged violations observed at the facility identified above.

Proposed Consent Order and Notice of Informal Fact Finding Proceeding

NOV Date(s)	TBRRO399678 - Issued July 12th, 2023
--------------------	--------------------------------------

The Responsible Party(ies) may resolve this matter quickly by entering into the enclosed Consent Order with DEQ within forty-five days from the date of this letter. If DEQ does not receive the signed Consent Order by that date, DEQ will proceed with conducting an Informal Fact Finding Proceeding as explained in Section II below.

I. PROPOSED CONSENT ORDER

DEQ wishes to resolve the alleged violations in the NOV by entering into a Consent Order with the Responsible Party(ies). DEQ's proposed Consent Order is enclosed for your review. The proposed Consent Order includes:

☒	A civil charge in the amount of <u>12,601.25</u>
☒	Injunctive relief (corrective actions) in Appendix A.

If you agree with the terms of the proposed Consent Order, please sign and date the Consent Order and send it within forty-five days from the date of this letter to:

Enforcement Specialist	Michael Puckett
Address	Virginia Department of Environmental Quality 901 Russel Drive Salem, VA 24153
Email	Michael.Puckett@deq.virginia.gov

The order is subject to public notice and comment before it becomes final. A copy of the fully executed order will be returned to you for implementation upon signature on behalf of DEQ.

II. NOTICE OF INFORMAL FACT FINDING PROCEEDING

You are hereby notified that if DEQ does not receive the signed Consent Order within forty-five days from the date of this letter, an Informal Fact Finding Proceeding will be held via conference call at the date and time listed below. At the scheduled time, dial the Call-In Number listed below, and enter the Access Code listed below when requested.

Proceeding Date	March 18th, 2024	Proceeding Time	2:00PM - 3:00PM
Call-In No.	+1 (312)757-3121	Access Code	253-160-749

If you have any difficulty accessing the conference call, please call:

Proposed Consent Order and Notice of Informal Fact Finding Proceeding

Agency Advocate	Michelle Callahan
Phone No.	(804)664-3893

The Informal Fact Finding Proceeding will be conducted pursuant to Va. Code §§ 2.2-4019 and 10.1-1186 to determine whether the Responsible Party(ies) violated the Virginia Code and Regulations as listed in the Findings of Fact and Conclusions of Law in Section C of the enclosed Consent Order. The Informal Fact Finding Proceeding will also determine the appropriateness of a civil penalty, injunctive relief, and/or delivery prohibition.

DEQ staff will request:

☒	A Special Order requiring the Responsible Party(ies) to:
☒	Pay the maximum civil penalty authorized by law, and pay attorneys' fees of 30% of the amount outstanding should DEQ have to refer collection of the civil penalty to the Department of Law.
☒	Comply with the Virginia Code and Regulations by completing the corrective actions listed in Appendix A of the enclosed proposed Consent Order.
☒	A Delivery Prohibition Decision determining that Tanks 1C, 2C and 3C at the Facility are in violation of the Underground Storage Tanks: Technical Standards and Corrective Action Requirements and/or the Petroleum Underground Storage Tank Financial Responsibility Requirements Regulations and ineligible for delivery, deposit, or acceptance of a regulated substance based on 9 VAC 25-580-370. ¹

To ascertain the facts in this matter, DEQ staff may rely upon DEQ's inspection report(s) for the Facility, the NOV(s), the Form 7530-2 Notification for USTs for the Facility, other public documents in DEQ files, and the information presented by witnesses. DEQ staff will also rely on applicable statutes, regulations, and DEQ guidance. Full texts of statutes, regulations, and DEQ guidance can be obtained at <http://www.deq.virginia.gov/LawsRegulations.aspx> or <http://lis.virginia.gov/> (statutes and regulations) and <http://townhall.virginia.gov/L/GDocs.cfm> (DEQ guidance). Copies will be provided upon request.

You may participate in the conference call yourself or by counsel or other qualified representative pursuant to Va. Code § 2.2-4019. At this proceeding, the Responsible Party(ies) will be able to present factual data, argument, or proof in connection with this case. A Presiding Officer will hear the evidence in this case and prepare a case decision to resolve any issues presented with respect to delivery prohibition. The Presiding Officer will prepare an independent Findings of Fact and Conclusions of Law and a draft Special Order for the Director's review. Then the Director may issue a Special Order under Va. Code § 10.1-1186, which may include both injunctive relief and a civil penalty.

Be advised that if you fail to attend or appear without good cause to an informal fact-finding proceeding conducted pursuant to Va. Code § 2.2-4019, the Presiding Officer may issue a default order regarding the subject of this notice. If a default order is issued, the Presiding Officer may conduct all

¹ You may request to be heard on the Emergency, Rural or Remote Exemption. 9 VAC 25-580-370(I) provides that if the Presiding Officer determines that a delivery prohibition violation exists, he or she can consider whether the threat posed by the violation is outweighed by the need for fuel from the UST(s) to meet an emergency situation or to meet the needs of a rural and remote area. If it is determined that such a condition outweighs the immediate risk of the violation, the Presiding Officer may defer imposition of delivery prohibition for up to 180 days. In every such case, the director shall consider (i) issuing a special order under the authority of subdivision 10 of § 10.1-1186 of the Code of Virginia prescribing a prompt schedule for abating the violation and (ii) imposing a civil penalty.

Proposed Consent Order and Notice of Informal Fact Finding Proceeding


further proceedings necessary to complete the adjudication and shall determine all issues in the adjudication, including those affecting you. Further, an order may be issued against you based on any admissions or other evidence without notice to you.

You will be notified of the results of the proceeding in accordance with Va. Code § 2.2-4019 and have the right to appeal any adverse decision in accordance with Va. Code § 2.2-4026.

If you have any questions or require assistance, please contact the following DEQ staff who will represent DEQ at this proceeding:

Agency Advocate	Michelle Callahan
Phone No.	(804)664-3893
Email	Michelle.Callahan@deq.virginia.gov

Sincerely,



R. Nelson Nail
Deputy Regional Director

Enclosure

**VIRGINIA DEPARTMENT OF ENVIRONMENTAL QUALITY
ENFORCEMENT ACTION - ORDER by CONSENT
ISSUED to**

**Om shree Incorporated - Mr. Pradeep Katwal
as the OWNER/OPERATOR of a UST FACILITY
and the RESPONSIBLE PARTY**

SECTION A: Purpose

This is a Consent Order issued under the authority of Va. Code § 62.1-44.15 for the purpose of resolving certain violations of the State Water Control Law and the applicable regulations.

SECTION B: Definitions

Unless the context clearly indicates otherwise, the terms used in this Consent Order have the meanings assigned to them in Va. Code §62.1-44.2 *et seq.*, 10.1-1182 *et seq.*, and 9VAC25-580-10 *et seq.*

SECTION C: Findings of Fact and Conclusions of Law

UST Owner		Om shree Incorporated		UST Operator		Mr. Pradeep Katwal	
Facility ID		2041607					
Facility Address		Street Address		11394 Big Island Highway			
		City	Big Island	VA	Zip Code	24526	
Inspection		6/22/20		Request for Compliance Action		9/21/22	
Warning Letter		2/24/23		Notice of Violation		7/12/23	
	UST #	Regulated Substance		Volume of UST (Gallons)			
	1C	Gasoline	☐	2,000			
	2C	Gasoline	☐	2,000			
	3C	Diesel	☐	2,000			
		Not Applicable					
		Not Applicable					
		Not Applicable					
Total # of UST		Total UST capacity at the Facility (Gallons)		6,000			

Violation	Observations and Legal Requirements	Civil Charge		Subtotal
	Failed to keep required records at the Facility, readily available at an alternative site, or make them immediately available upon request. 9VAC25-580-120: Reporting and Recordkeeping	\$ 0	☐	\$ 0
		# of Violations	1	
✓	Failed to properly perform, repair, replace, test, or provide a method, or combination of methods, of release detection for tanks, and/or operation of electronic and mechanical components for USTs at the Facility. 9VAC25-580-110: Repairs Allowed 9VAC25-580-130: General Requirements for all UST Systems 9VAC25-580-140: Requirements for Petroleum UST Systems 9VAC25-580-160: Methods of Release Detection for Tanks	\$ 712	☐	\$ 2,136
		# of Violations	3	
	Failed to properly perform, repair, replace, test, or provide release detection for piping, and/or operation of electronic and mechanical components for USTs at the Facility. 9VAC25-580-110: Repairs Allowed 9VAC25-580-130: General Requirements for all UST Systems 9VAC25-580-140: Requirements for Petroleum UST Systems 9VAC25-580-170: Methods of Release Detection for Piping	\$ 0	☐	\$ 0
		# of Violations		
	Failed to provide, operate, repair, test and/or maintain corrosion protection of the UST system. 9VAC25-580-50: Performance Standards for New UST Systems 9VAC25-580-60: Upgrading of Existing UST Systems 9VAC25-580-90: Operation and Maintenance of Corrosion Protection 9VAC25-580-110: Repairs Allowed	\$ 0	☐	\$ 0
		# of Violations		
	Failed to provide overfill and/or spill prevention / equipment that will prevent a release into the environment. 9VAC25-580-50: Performance Standards for New UST Systems 9VAC25-580-60: Upgrading of existing UST Systems	\$ 0	☐	\$ 0
		# of Violations		
✓	Failed to conduct or properly conduct walkthrough inspections. 9VAC25-580-85: Periodic operation and maintenance walkthrough inspections	\$ 712	☐	\$ 712
		# of Violations	1	
✓	Failed to submit a UST notification form or an amended notification form regarding a change in ownership, tank status, tank/piping systems, or substance stored within 30 days after such change or upgrade occurs or is brought into use. 9VAC25-580-70: Notification Requirements	\$ 305	☐	\$ 305
		# of Violations	1	

Violation	Observations and Legal Requirements	Civil Charge		Subtotal
✓	Failed to complete the required training and/or designate Class A, Class B, and/or Class C operators and/or failed to provide written instructions or emergency procedures. 9VAC25-580-125: Operator Training	\$ 712	1	\$ 712
		# of Violations	1	
✓	Failed to properly conduct testing and/or test spill prevention equipment, overfill equipment, and/or containment sumps. 9VAC25-580-82: Periodic Testing	\$ 712	3	\$ 2,136
		# of Violations	3	
	Failed to report a suspected release or unusual operating condition within 24 hours. 9VAC25-580-190: Reporting of Suspected Releases 9VAC25-580-220: Reporting and Cleanup of Spills and Overfills	\$ 0	0	\$ 0
		# of Violations		
	Failed to immediately investigate and confirm all suspected releases of regulated substances requiring system test/site check and reporting within seven days. 9VAC25-580-210: Release Investigation and Confirmation Steps	\$ 0	0	\$ 0
		# of Violations		
	Failed to contain and immediately clean up a spill or overfill that results in a release to the environment that exceeds 25 gallons or that causes a sheen on nearby surface water; and/or take immediate action to prevent further release or migration of a regulated substance; and/or failed to identify and mitigate fire, explosion and vapor hazards; and/or failed to remedy hazards posed by contaminated soils; and/or measure for a release where contamination is most likely; and/or failed to submit an initial abatement report; and/or failed to investigate and remove free product. 9VAC25-580-220: Reporting and Cleanup of Spills and Overfills 9VAC25-580-240: Initial Response 9VAC25-580-250: Initial Abatement Measure and Site Check 9VAC25-580-270: Free Product Removal	\$ 0	0	\$ 0
		# of Violations		
	Failed to assemble information about the site and the nature of the release, including information gained while confirming the release or completing the initial abatement measures. 9VAC25-580-260: Site Characterization	\$ 0	0	\$ 0
		# of Violations		

Violation	Observations and Legal Requirements	Civil Charge		Subtotal
	Failed to notify 30 days before switching to a specified regulated substance and/or failed to demonstrate proper compatibility. 9VAC25-580-100: Compatibility	\$ 0		\$ 0
		# of Violations		
	Failed to investigate off-site impacts to determine if the UST system is the source. 9VAC25-580-200: Investigation Due to Off-Site Impacts	\$ 0		\$ 0
		# of Violations		
	Failed to submit a corrective action plan, with all necessary information, according to the required schedule, or perform corrective action to address contaminated soils and groundwater. 9VAC25-580-270: Free Product Removal 9VAC25-580-280: Corrective Action Plan	\$ 0		\$ 0
		# of Violations		
	Failed to follow the requirements to temporarily close a UST system and/or failed to keep temporarily closed UST system in compliance with requirements. 9VAC25-580-310: Temporary Closure	\$ 0		\$ 0
		# of Violations		
	Delivered or accepted a regulated substance into an ineligible UST. 9VAC25-580-370: Requirements for Delivery Prohibition	\$ 0		\$ 0
		# of Violations		
	Failed to permanently close a UST system that does not meet the new UST or UST upgrade requirements. 9VAC25-580-50: Performance Standards for New UST systems 9VAC25-580-60: Upgrading of existing UST systems 9VAC25-580-310: Temporary Closure	\$ 0		\$ 0
		# of Violations		
	Failed to demonstrate financial responsibility for taking corrective action and for compensating third parties for bodily injury and property damage caused by accidental releases arising from the operation of petroleum USTs. 9VAC25-590-40: Amount and Scope of Financial Responsibility Requirement. 9VAC25-590-50: Allowable Mechanisms	\$ 0		\$ 0
		# of Violations		
	Failed to maintain evidence of all financial assurance mechanisms used to demonstrate financial responsibility. 9VAC25-590-160: Recordkeeping	\$ 0		\$ 0
		# of Violations		
Civil Charge Subtotal		\$ 6,001		

Aggravating Factors		
	Additional Civil Charge Assessment	Subtotal
Degree of Culpability	0.25 	\$ 1,500.25
Consent Order in another media Program within 36 months	0.00 	\$ 0.00
Consent Order in the same media program within 36 months	0.00 	\$ 0.00
Aggravating Factors Subtotal		\$ 1,500.25
Civil Charge Subtotal and Aggravating Factor Subtotal		\$ 7,501.25
Civil Charge Reduction	0.00 	\$ 0.00
Economic Benefit of Noncompliance		\$ 5,100.00
In accordance with 62.1-44.15(8e), the Responsible Party's Ability to Pay was evaluated and it was determined that there is an ability to pay.	Yes	
Total Civil Charge		\$ 12,601.25
Based on the results of staff observations, the Department concludes that the Responsible Party has violated Va. Code and Regulations as identified herein.		

SECTION D: Agreement and Order

Accordingly, by virtue of the authority granted it in Va. Code §§ 62.1-44.15, the Department orders the Responsible Party, and the Responsible Party agrees to:

☒ Perform the actions described in Appendix A of this Order if this box is checked and

Pay the total civil charge of \$ 12,601.25 in settlement of the violations cited in this Order in accordance with the following:

☒ Within 30 days of the effective date of the Order, or

☐ In accordance with the following payment schedule:

Due Date	Amount

Payment shall be made by check, certified check, money order or cashier's check payable to the "Treasurer of Virginia," and delivered to:

Receipts Control
Department of Environmental Quality
Post Office Box 1104
Richmond, VA 23218

The Responsible Party shall include its Federal Employer Identification Number (FEIN), if applicable, with the civil charge payment and shall indicate that the payment is being made in accordance with the requirements of this Order for deposit into the Virginia Petroleum Storage Tank Fund (VPSTF). If the Department has to refer collection of moneys due under this Order to the Department of Law, Responsible Party shall be liable for attorneys' fees of 30% of the amount outstanding.

SECTION E: Administrative Provisions

1. The Department may modify, rewrite, or amend this Order with the consent of the Responsible Party for good cause shown by the Responsible Party, or on its own motion pursuant to the Administrative Process Act, Va. Code § 2.2-4000 *et seq.*, after notice and opportunity to be heard.
2. This Order addresses and resolves only those violations specifically identified in Section C of this Order. This Order shall not preclude the Department or the Director from taking any action authorized by law, including but not limited to: (1) taking any action authorized by law regarding any additional, subsequent, or subsequently discovered violations; (2) seeking subsequent remediation of the facility; or (3) taking subsequent action to enforce the Order.
3. For purposes of this Order and subsequent actions with respect to this Order only, the Responsible Party admits the jurisdictional allegations, and agrees not to contest, but neither admits nor denies, the findings of fact and conclusions of law in this Order.
4. The Responsible Party consents to venue in the Circuit Court of the City of Richmond for any civil action taken to enforce the terms of this Order.
5. The Responsible Party declares it has received fair and due process under the Administrative Process Act and the State Water Control Law and it waives the right to any hearing or other administrative proceeding authorized or required by law or regulation, and to any judicial review of any issue of fact or law contained herein. Nothing herein shall be construed as a waiver of the right to any administrative proceeding for, or to judicial review of, any action taken by the Department to modify, rewrite, amend, or enforce this Order.
6. Failure by the Responsible Party to comply with any of the terms of this Order shall constitute a violation of an order of the Department. Nothing herein shall waive the initiation of appropriate enforcement actions or the issuance of additional orders as appropriate by the Department or the Director as a result of such violations. Nothing herein shall affect appropriate enforcement actions by any other federal, state, or local regulatory authority.

7. If any provision of this Order is found to be unenforceable for any reason, the remainder of the Order shall remain in full force and effect.
8. The Responsible Party shall be responsible for failure to comply with any of the terms and conditions of this Order unless compliance is made impossible by earthquake, flood, other acts of God, war, strike, or such other unforeseeable circumstances beyond its control and not due to a lack of good faith or diligence on its part. The Responsible Party shall demonstrate that such circumstances were beyond its control and not due to a lack of good faith or diligence on its part. The Responsible Party shall notify the DEQ Regional Director verbally within 24 hours and in writing within three business days when circumstances are anticipated to occur, are occurring, or have occurred that may delay compliance or cause noncompliance with any requirement of the Order. Such notice shall set forth:
 - a. the reasons for the delay or noncompliance;
 - b. the projected duration of any such delay or noncompliance;
 - c. the measures taken and to be taken to prevent or minimize such delay or noncompliance; and
 - d. the timetable by which such measures will be implemented and the date full compliance will be achieved.

Failure to so notify the Regional Director verbally within 24 hours and in writing within three business days, of learning of any condition above, which the parties intend to assert will result in the impossibility of compliance, shall constitute a waiver of any claim to inability to comply with a requirement of this Order.

9. This Order is binding on the parties hereto and any successors in interest, designees and assigns, jointly and severally.
10. This Order shall become effective upon execution by both the Director or his designee and The Responsible Party. Nevertheless, the Responsible Party agrees to be bound by any compliance date which precedes the effective date of this Order.
11. This Order shall continue in effect until:
 - a. The Director or his designee terminates the Order after the Responsible Party has completed all of the requirements of the Order;
 - b. The Responsible Party petitions the Director or his designee to terminate the Order after it has completed all of the requirements of the Order and the Director or his designee approves the termination of the Order; or
 - c. The Director or Department terminates the Order in his or its sole discretion upon 30 days' written notice to the Responsible Party.

Termination of this Order, or any obligation imposed in this Order, shall not operate to relieve the Responsible Party from its obligation to comply with any statute, regulation, permit condition, other order, certificate, certification, standard, or requirement otherwise applicable.

12. Any plans, reports, schedules or specifications attached hereto or submitted by the Responsible Party and approved by the Department pursuant to this Order are incorporated into this Order. Any non-compliance with such approved documents shall be considered a violation of this Order.

13. The undersigned representative of the Responsible Party certifies that he or she is a responsible official [or officer] authorized to enter into the terms and conditions of this Order and to execute and legally bind the Responsible Party to this document. Any documents to be submitted pursuant to this Order shall also be submitted by a responsible official of the Responsible Party.
14. This Order constitutes the entire agreement and understanding of the parties concerning settlement of the violations identified in Section C of this Order, and there are no representations, warranties, covenants, terms or conditions agreed upon between the parties other than those expressed in this Order.
15. By its signature below, the Responsible Party voluntarily agrees to the issuance of this Order.

And it is so ORDERED.

DEQ Signee Signature

Date

DEQ Signee Name

Title

As the owner/operator of the UST system identified herein, I hereby certify that I am the Responsible Party and acknowledge that there are no material facts in dispute with respect to the violations as identified in this consent order.

Date: By: ,

Responsible Party Name

Title

DEQ Contact

Unless otherwise specified in this Order, the Responsible Party shall submit all requirements of Appendix A of this Order to:

DEQ Blue Ridge Regional Office
Attn: Michael Puckett
901 Russell Dr.
Salem, VA 24153

Michael.Puckett@DEQ.Virginia.gov

APPENDIX A SCHEDULE OF COMPLIANCE

The Responsible Party shall take the following actions:

	Correction to be Performed	Due Date
	Provide release detection for the UST system as required in 9VAC25-580-140.	
	Provide records for ___ months in accordance with 9VAC25-580-120 demonstrating compliance with all release detection requirements as required in 9VAC25-580-180.	
	Provide records demonstrating the automatic line leak detector has been tested within the past 12 months, presenting passing results in accordance with the performance requirements set forth in 9VAC25-580-130 and 170.	
	Provide records demonstrating line tightness testing has been completed within the past 12 months, presenting passing results in accordance with the performance requirements set forth in 9VAC25-580-130 and 170.	
	Provide records demonstrating the proper repair and/or replacement of electronic and mechanical components of a UST system upon failed testing results, is in accordance with 9VAC25-580-110.	
	Provide records demonstrating that the install and/or repair of the necessary equipment to provide adequate corrosion protection on the UST system is in accordance with 9VAC25-580-90 and 9VAC25-580-110.	
	Complete cathodic protection system testing in accordance with 9VAC25-580-90 and submit copies of these cathodic protection system test results in accordance with 9VAC25-580-120.	
	Submit documentation that the impressed current cathodic protection system is inspected every 60 days in accordance with 9VAC25-580-90(3).	
	Provide records demonstrating periodic testing and inspections of spill/overfill prevention equipment and containment sumps has been performed within the past 12 months in accordance with 9VAC25-580-82.	
	Submit an updated Notification for the UST system in accordance with 9VAC25-580-70.	
	Submit documentation demonstrating financial responsibility in accordance with 9VAC25-590-10 <i>et seq.</i>	
	Submit training documentation for all the Class A, B, and C operators, including a current list of operators and written instructions or procedures for Class C operators. All training documentation shall verify training has been conducted in accordance with 9VAC25-580-120, and - 125.	
✓	Submit results of <u>3</u> months of walkthrough inspections results in accordance with 9VAC25-580-85.	Four months from the effective date of Order
✓	Submit annual walkthrough inspections results in accordance with 9VAC25-580-85.	Four months from the effective date of Order

APPENDIX A SCHEDULE OF COMPLIANCE

The Responsible Party shall take the following actions:

	Correction to be Performed	Due Date
✓	Provide proof of replacement of tank stick with a new one marked in 1/2 inch increments and submit documentation such as a receipt and/or a letter also including photographic proof.	Two months from the effective date of Order
✓	Submit Emergency Response Procedures regarding fuel emergencies to the above-noted contact.	Two months from the effective date of Order
✓	Submit a properly completed Notification for Underground Storage Tanks Form 7530 to the above-noted contact.	Two months from the effective date of Order