



Commonwealth of Virginia

VIRGINIA DEPARTMENT OF ENVIRONMENTAL QUALITY

www.deq.virginia.gov

Stefanie K. Taillon
Secretary of Natural and Historic Resources

Michael S. Rolband, PE, PWD, PWS Emeritus
Director

August 4, 2025

Mr. D. Tony Qorri
Vice President, Construction
DataBank Holdings Ltd
400 S Akard Street, Suite 100
Dallas, TX 75202

Location: Loudoun County
Registration No.: 73743

Dear Mr. Qorri:

Attached is a permit to construct and operate a data center in accordance with the provisions of the Virginia State Air Pollution Control Board Regulations for the Control and Abatement of Air Pollution. This permit document combines the terms and conditions from, and supersedes, the permit document dated June 1, 2022.

In the course of evaluating the application and arriving at a final decision to approve the project, the Department of Environmental Quality (DEQ) deemed the application complete on July 17, 2025.

This permit contains legally enforceable conditions. Failure to comply may result in a Notice of Violation and/or civil charges. Please read all permit conditions carefully.

This permit approval to construct and operate shall not relieve DataBank Holdings Ltd of the responsibility to comply with all other local, state, and federal permit regulations.

The proposed diesel fired emergency engine generator sets (engine gen-sets) may be subject to 40 CFR 63, Maximum Achievable Control Technology, (MACT) Subpart ZZZZ and 40 CFR 60, New Source Performance Standard (NSPS), Subpart IIII. Virginia has not accepted delegation of these rules. In summary, the units may be required to comply with certain federal emission standards and operating limitations. The Department of Environmental Quality (DEQ) advises you to review the referenced MACT and NSPS to ensure compliance with applicable emission and operational limitations. As the owner/operator you may be also responsible for any monitoring, notification, reporting and recordkeeping requirements of the MACT and NSPS. Notifications shall only be sent to EPA, Region III.

To review any federal rules referenced in the above paragraph or in the attached permit, the US Government Publishing Office maintains the text of these rules at www.ecfr.gov, Title 40, Part 60 and 63.

The Board's Regulations as contained in Title 9 of the Virginia Administrative Code 5-170-200 provide that you may request a formal hearing from this case decision by filing a petition with the Board within 30 days after this case decision notice was mailed or delivered to you. Please consult the relevant regulations for additional requirements for such requests.


As provided by Rule 2A:2 of the Supreme Court of Virginia, you have 30 days from the date you actually received this permit or the date on which it was mailed to you, whichever occurred first, within which to initiate an appeal of this decision by filing a Notice of Appeal with:

Michael S. Rolband, Director
Department of Environmental Quality
P. O. Box 1105
Richmond, VA 23218

If this permit was delivered to you by mail, three days are added to the thirty-day period in which to file an appeal. Please refer to Part Two A of the Rules of the Supreme Court of Virginia for information on the required content of the Notice of Appeal and for additional requirements governing appeals from decisions of administrative agencies.

If you have any questions concerning this permit, please contact Ms. Katie DeVoss at (571) 866-6090 or katie.devoss@deq.virginia.gov.

Sincerely,



Justin A. Wilkinson, Regional Air Permit Manager
Virginia Department of Environmental Quality
justin.wilkinson@deq.virginia.gov
Northern Regional Office
13901 Crown Court, Woodbridge, VA 22193
(703) 583-3800

JAW/KD/73743 mNSR (2025-08-04)

Attachment: Permit



Commonwealth of Virginia

VIRGINIA DEPARTMENT OF ENVIRONMENTAL QUALITY

www.deq.virginia.gov

Stefanie K. Taillon
Secretary of Natural and Historic Resources

Michael S. Rolband, PE, PWD, PWS Emeritus
Director

STATIONARY SOURCE PERMIT TO CONSTRUCT AND OPERATE

This permit document supersedes and combines the terms and conditions from the mNSR permit document dated June 1, 2022.

In compliance with the Federal Clean Air Act and the Commonwealth of Virginia Regulations for the Control and Abatement of Air Pollution,

DataBank Holdings Ltd
400 S Akard Street, Suite 100
Dallas, TX 75202
Registration No.: 73743

is authorized to construct and operate

emergency diesel engine gen-sets


located at

IAD-1, IAD-3, and IAD-4
21635, 21630, and 21625 Red Rum Drive
Ashburn, VA 20147
(Loudoun County)

in accordance with the Conditions of this permit.

Approved on

August 4, 2025.


Justin A. Wilkinson, Regional Air Permit Manager
Virginia Department of Environmental Quality

Permit consists of 22 pages.
Permit Conditions 1 to 34.

INTRODUCTION

This permit approval is based on and combines permit terms and conditions in accordance with 9VAC5-80-1255 from the following permit approvals and the respective permit applications:

- mNSR permit dated August 4, 2025, based on the permit application dated March 24, 2025, including supplemental information dated May 7, 2025, June 4, 2025, and July 17, 2025;
- mNSR permit dated June 1, 2022, based on the permit application dated August 23, 2021, including supplemental information dated May 27, 2022;
- mNSR permit dated May 18, 2017, based on the permit application dated February 1, 2017;
- mNSR permit dated September 28, 2012, based on the permit application dated May 15, 2012;
- mNSR permit dated August 5, 2010, based on the permit application dated May 26, 2010, including supplemental information dated June 9, 2010, and June 17, 2010;
- mNSR administrative amendment dated June 11, 2009; and
- mNSR permit dated May 8, 2009, based on the permit application dated March 25, 2009, including supplemental information dated April 9, 2009.

Words or terms used in this permit shall have meanings as provided in 9VAC5-10-10 of the State Air Pollution Control Board Regulations for the Control and Abatement of Air Pollution. The regulatory reference or authority for each condition is listed in parentheses () after each condition. The enabling permit program, or permit programs is provided below each permit condition in the regulatory authority parenthetical as follows: 9VAC5-80-850 for Article 5, 9VAC5-80-1180 for Article 6, 9VAC5-80-1985 for Article 8, and 9VAC5-80-2050 for Article 9. The most recent effective date for a term or condition is listed in brackets []. When identical conditions for one or more emission units are combined, the effective date listed in this permit does not alter the prior effective date(s) for any such conditions as issued in a previous permit action. In accordance with 9VAC5-80-1120 F, any condition not marked as state-only enforceable (SOE) is state and federally enforceable.

Annual requirements to fulfill legal obligations to maintain current stationary source emissions data will necessitate a prompt response by the permittee to requests by the DEQ or the Board for information to include, as appropriate: process and production data; changes in control equipment; and operating schedules. Such requests for information from the DEQ will either be in writing or by personal contact.

The availability of information submitted to the DEQ or the Board will be governed by applicable provisions of the Freedom of Information Act, §§ 2.2-3700 through 2.2-3714 of the Code of Virginia, § 10.1-1314 (addressing information provided to the Board) of the Code of Virginia, and 9VAC5-170-60 of the State Air Pollution Control Board Regulations. Information provided to federal officials is subject to appropriate federal law and regulations governing confidentiality of such information.

Equipment List - Equipment at this facility covered by this permit consists of:

Equipment to be constructed:

| Ref. No(s). | Equipment Description | Maximum Rated Capacity (each) | Delegated Federal Requirements | Original Permit Date |
|----------------------|---|--------------------------------------|---------------------------------------|-----------------------------|
| EG4-1 through EG4-12 | Twelve (12) Cummins emergency gen sets with QSK78-G36 diesel engines (Generator Model: C3000D6EB) | 4,316 bhp 3,000 ekW | None | August 4, 2025 |
| EG4BB1 and EG4BB2 | Two (2) Cummins emergency gen sets with QST30-G5 diesel engines (Generator Model: 1000DQFAD) | 1,482 bhp 1,000 ekW | None | August 4, 2025 |

Equipment previously constructed:

| Ref. No(s). | Equipment Description | Maximum Rated Capacity (each) | Delegated Federal Requirements | Original Permit Date |
|----------------------------|--|--------------------------------------|---------------------------------------|-----------------------------|
| EG2-1 through EG2-26 | (26) Caterpillar 3516E emergency diesel engine gen-sets | 4,393 bhp 3,000 ekW | None | June 1, 2022 |
| EG2BB | One (1) Caterpillar C18 emergency diesel engine gen-set | 1,112 bhp 750 ekW | None | June 1, 2022 |
| 2C, 3A, 3B, 3C, 3D, and 3S | Six (6) Caterpillar 3516C emergency diesel engine gen-sets | 2,937 bhp 2,000 ekW | None | May 18, 2017 |
| 2A, 2B, and 2S | Three (3) Caterpillar 3516C emergency diesel engine gen-sets | 2,937 bhp 2,000 ekW | None | September 28, 2012 |
| 1A, 1C, 1D, 1E, and 1S | Five (5) Caterpillar 3516C emergency diesel engine gen-sets | 2,937 bhp 2,000 ekW | None | August 5, 2010 |

Specifications included in the above tables are for informational purposes only and do not form enforceable terms or conditions of the permit.

PROCESS REQUIREMENTS

1. Emission Controls –

- a. Nitrogen oxides (NO_x) emissions from the emergency diesel engine gen-sets (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, and 2S) shall be controlled by turbocharged engines, after coolers, and low NO_x emission packages.
- b. Nitrogen oxides (NO_x) emissions from each emergency diesel engine gen-set (Ref. Nos. 2C, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, and EG2BB) shall be controlled by electronic fuel injection, turbocharged engines, and after coolers. The permittee shall maintain documentation that demonstrates the control devices have been installed on each emergency diesel engine gen-set.
- c. Nitrogen oxides (NO_x) emissions from each emergency diesel engine gen-set (Ref. Nos. EG4-1 through EG4-12, EG4BB1, and EG4BB2) shall be controlled by engine design.

(9VAC5-80-1180 and 9VAC5-50-260) [8/4/2025]

2. **Emission Controls** – Visible emissions, particulate matter (PM₁₀ and PM_{2.5}) emissions, carbon monoxide (CO) emissions, volatile organic compound (VOC) emissions, and nitrogen oxide (NO_x) emissions from the emergency diesel engine gen-sets (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) shall be controlled by the use of good operating practices and performing appropriate maintenance in accordance with the manufacturer recommendations. In addition, the permittee may only change those settings that are permitted by the manufacturer and do not increase air emissions.

(9VAC5-80-1180 and 9VAC5-50-260) [8/4/2025]

3. Monitoring Devices –

- a. Fuel Flow: Each emergency diesel engine gen-set (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) shall be equipped with a device to continuously measure and record individual fuel consumption (in gallons) for each diesel engine gen-set.
- b. Engine Operating Hours: Each emergency diesel engine gen-set (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) shall be equipped with a non-resettable hour metering device to monitor the operating hours.

The monitoring devices (as required in a. and b. above) shall be observed by the permittee at a minimum frequency of once per day when the emergency diesel engine gen-set is operated. The permittee shall keep a log of these observations.

Each monitoring device shall be installed, maintained, calibrated (as appropriate) and operated in accordance with approved procedures which shall include, as a minimum, the manufacturer's written requirements or recommendations. The details of the monitoring device calibrations are to be arranged with the Regional Air Compliance Manager of the DEQ's NRO.

Each monitoring device shall be provided with adequate access for inspection and shall be in operation when the diesel engine gen-sets are operating.
(9VAC5-80-1180 D) [8/4/2025]

OPERATING LIMITATIONS

4. **Emergency Power Generation** – The emergency diesel engine gen-sets (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) shall only be operated in the following modes:
 - a. In situations that arise from sudden and reasonably unforeseeable events where the primary energy or power source is disrupted or disconnected due to conditions beyond the control of an owner or operator of a facility including:
 - i. A failure of the electrical grid;
 - ii. On-site disaster or equipment failure; or
 - iii. Public service emergencies such as flood, fire, natural disaster, or severe weather conditions.
 - b. For participation in an ISO-declared emergency, where an ISO emergency is:
 - i. An abnormal system condition requiring manual or automatic action to maintain system frequency, to prevent loss of firm load, equipment damage, or tripping of system elements that could adversely affect the reliability of an electric system or the safety of persons or property;
 - ii. Capacity deficiency or capacity excess conditions;
 - iii. A fuel shortage requiring departure from normal operating procedures in order to minimize the use of such scarce fuel;
 - iv. Abnormal natural events or man-made threats that would require conservative operations to posture the system in a more reliable state; or

- v. An abnormal event external to the ISO service territory that may require ISO action.
- c. For scheduled maintenance checks and readiness testing (Scheduled MCRT).
- d. For unscheduled maintenance, testing, and operational training.
- e. For the integration operational period, which is the period of time beginning with the first time the affected unit is started on-site and ending when the affected unit is fully integrated with the sources electrical system.

(9VAC5-80-1180) [8/4/2025]

5. **Operation of the Engine Gen-Sets** – The permittee shall operate and maintain each emergency diesel engine gen-set (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) and control device according to the manufacturer’s written instructions or procedures developed by the permittee that are approved by the engine manufacturer. In addition, the permittee may only change those settings that are permitted by the manufacturer and do not increase air emissions.
(9VAC5-80-1180) [8/4/2025]
6. **Operating Limitations (Ozone Season)** – No emergency diesel engine gen-set (Ref. Nos. EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) shall be operated for scheduled maintenance checks (Scheduled MCRT), readiness testing, stack testing, or operational training (that involves fuel combustion) between the hours of 7 a.m. to 5 p.m. any day during May 1 through September 30. The permittee may petition the Regional Air Compliance Manager of DEQ’s NRO for exceptions to this requirement, with approvals made on a case by-case basis.
(9VAC5-80-1180) [8/4/2025]
7. **Operating Limitations (Ozone Season) – Integration Operational Period** – During the integration operational period of each emergency diesel engine gen-set (Ref. Nos. EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2), any operation of the unit (that involves fuel combustion) between the hours of 7 a.m. to 5 p.m. any day during the ozone season of May 1 through September 30 shall only occur if the forecast Air Quality index (AQI) for ozone as published on the AirNow website (<https://airnow.gov>) for Northern Virginia for that day is less than or equal to 100. In the event that AirNow-EnviroFlash (www.enviroflash.info) issues an Air Alert for Northern Virginia for a day which the forecasted AQI for ozone was less than or equal to 100, operation of each unit (which involves fuel combustion) shall be minimized to the maximum extent practical.
(9VAC5-80-1180) [8/4/2025]

8. **Operating Hours—**

- a. Each individual emergency diesel engine gen-set (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) shall not operate more than 500 hours per year for all purposes (as provided in Condition 4), calculated monthly as the sum of each consecutive 12 month period.
- b. Each individual emergency diesel engine gen-set (Ref. Nos. 2C, 3A, 3B, 3C, 3D, 3S) shall not operate more than 100 hour per year for scheduled maintenance checks and readiness testing, unscheduled maintenance, testing, and operational training (as provided in Conditions 4.c and 4.d), calculated monthly as the sum of each consecutive 12 month period.
- c. Each individual emergency diesel engine gen-set (Ref. Nos. EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) shall not operate more than 25 hours per year for scheduled maintenance checks and readiness testing (Scheduled MCRT, as provided in Condition 4.c), calculated monthly as the sum of each consecutive 12 month period.

Compliance for the consecutive 12-month period shall be demonstrated monthly by adding the total for the most recently completed calendar month to the individual monthly totals for the preceding 11 months.

(9VAC5-80-1180) [8/4/2025]

9. **Fuel Specification** – The approved fuel for the emergency diesel engine gen-sets (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) is ultra-low sulfur diesel fuel oil, and shall meet the specifications below:

ULTRA LOW SULFUR DIESEL FUEL OIL:

- a. Does not exceed the American Society for Testing and Materials (ASTM) specification, D975, for grade ultra-low sulfur 2-D or grade 2-D S15, or
- b. Has a maximum sulfur content not to exceed 0.0015% by weight (15 ppm), and either a minimum cetane number of 40 or maximum aromatic content of 35 volume percent.

Exceedance of these specifications may be considered credible evidence of an exceedance of emission limits. A change in the fuel type or the fuel sulfur content may require a permit to modify and operate.

(9VAC5-80-1180 and 9VAC5-50-260) [8/4/2025]

10. **Fuel Certification** – The permittee shall obtain a certification from the fuel supplier with each shipment of diesel fuel. Each fuel supplier certification shall include the following:
- a. The name of the fuel supplier;
 - b. The date on which the diesel fuel was received;
 - c. The quantity of diesel fuel delivered in the shipment; and
 - d. A statement that the diesel fuel:
 - i. complies with the ASTM specifications for Grade No. 1-D S15 or Grade No. 2-D S15 (also known as ultra-low sulfur diesel (ULSD)); or
 - ii. has a sulfur content per shipment not to exceed 0.0015% by weight (15 ppm) and either a minimum cetane number of forty or maximum aromatic content of thirty-five percent by volume.

Alternatively, the permittee must obtain approval from DEQ's NRO's Regional Air Compliance Manager, if other documentation will be used to certify the diesel fuel type.

Fuel sampling and analysis, independent of that used for certification, as may be periodically required or conducted by DEQ may be used to determine compliance with the fuel specifications stipulated in Condition 9. Exceedance of these specifications may be considered credible evidence of the exceedance of emission limits.
(9VAC5-80-1180) [8/4/2025]

11. **Diesel Fuel Throughput Limits** –

- a. The emergency diesel engine gen-set (Ref. No. EG2BB) shall consume no more than 1,234 gallons of diesel fuel, calculated daily as the sum of each consecutive 365-day period (all uses).
- b. The emergency diesel engine gen-sets (Ref. Nos. EG4BB1 and EG4BB2) combined shall consume no more than 3,121 gallons of diesel fuel, calculated daily as the sum of each consecutive 365-day period (all uses).

Compliance for the consecutive 365-day period shall be demonstrated daily by adding the total for the most recently completed calendar day to the individual daily totals for the preceding 364 days.
(9VAC5-80-1180) [8/4/2025]

12. **Formulaic Diesel Fuel Throughput Limits** – The diesel engine gen-sets (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, and EG4-1 through EG4-12) for all operations shall only consume a combined quantity of diesel fuel (in gallons) each consecutive 365-day period, as demonstrated by using the following equation:

$$\frac{\text{Group 1 Fuel Consumption}}{681,086 \text{ gallons}} + \frac{\text{Group 2 Fuel Consumption}}{506,548 \text{ gallons}} + \frac{\text{Group 3 Fuel Consumption}}{711,787 \text{ gallons}} \leq 1$$

| Engine Gen Set Group | Ref. Nos. | Engine Gen Set Model (Rating) |
|----------------------|--|--|
| Group 1 | 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S | Caterpillar 3516C (2,000 ekW) |
| Group 2 | EG2-1 through EG2-26 | Caterpillar 3516E (3,000 ekW) |
| Group 3 | EG4-1 through EG4-12 | Cummins C3000D6EB/QSK78-G36 engine (3,000 ekW) |

Compliance for the consecutive 365-day period shall be demonstrated daily by adding the total for the most recently completed calendar day to the individual daily total for the preceding 364 days.

(9VAC5-80-1180) [8/4/2025]

EMISSION LIMITS

13. **Emission Limits (Hourly)** – Emissions from the operation of each emergency diesel engine gen-set (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) shall not exceed the limits specified below:

| Pollutant | Caterpillar 3516C (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, and 3S) | Caterpillar 3516E (Ref. Nos. EG2-1 through EG2-26) | Caterpillar C18 (Ref. No. EG2BB) |
|--|---|---|-------------------------------------|
| Nitrogen Oxides (NO _x as NO ₂) | 38.85 lbs/hr | 54.53 lbs/hr | 14.35 lbs/hr |
| Carbon Monoxide (CO) | 2.19 lbs/hr | 11.62 lbs/hr | 4.74 lbs/hr |
| Volatile Organic Compounds (VOC) | 1.14 lbs/hr | 0.58 lbs/hr | 1.92 lbs/hr |
| Particulate Matter (PM ₁₀) | 0.62 lbs/hr | 0.92 lbs/hr | 0.33 lbs/hr |
| Particulate Matter (PM _{2.5}) | 0.62 lbs/hr | 0.92 lbs/hr | 0.33 lbs/hr |

| Pollutant | Cummins C3000D6EB/ QSK78-G36 engine (Ref. Nos. EG4-1 through EG4-12) | Cummins QST30-G5 (Ref. Nos. EG4BB1 and EG4BB2) |
|--|---|---|
| Nitrogen Oxides (NO _x as NO ₂) | 55.76 lbs/hr | 16.13 lbs/hr |
| Carbon Monoxide (CO) | 3.93 lbs/hr | 2.70 lbs/hr |
| Volatile Organic Compounds (VOC) | 1.18 lbs/hr | 0.29 lbs/hr |
| Particulate Matter (PM ₁₀) | 0.61 lbs/hr | 0.53 lbs/hr |
| Particulate Matter (PM _{2.5}) | 0.61 lbs/hr | 0.53 lbs/hr |

Compliance with these emission limits shall be based on the proper operation and maintenance of the emergency diesel engine gen-sets or by testing, if required.
(9VAC5-80-1180 and 9VAC5-50-260) [8/4/2025]

14. **Emission Limits (Annual)** – Emissions from the operation of the emergency diesel engine gen-sets (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, and EG4-1 through EG4-12) shall not exceed the limits specified below:

| Pollutant | Caterpillar 3516C, Caterpillar 3516E, and Cummins C3000D6EB/QSK78-G36 engine (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, and EG4-1 through EG4-12) |
|--|--|
| Nitrogen Oxides (NO _x as NO ₂) | 95.87 tpy |
| Carbon Monoxide (CO) | 42.01 tpy |
| Volatile Organic Compounds (VOC) | 12.62 tpy |
| Particulate Matter (PM ₁₀) | 6.09 tpy |
| Particulate Matter (PM _{2.5}) | 6.09 tpy |

These emissions are derived from the estimated overall emission contribution from operating limits. Exceedance of the operating limits may be considered credible evidence of the exceedance of emission limits. Compliance with the annual emission limits may be determined as stated in Conditions 1, 2, 9, 12, and 13.
(9VAC5-80-1180) [8/4/2025]

15. **Emission Limits (Annual Facility-Wide)** – Emissions from the operation of the emergency diesel engine gen-sets (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) shall not exceed the limits specified below:

| Pollutant | All Units (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) |
|---|--|
| Nitrogen Oxides (NO _x as NO ₂) | 96.50 tpy |
| Carbon Monoxide (CO) | 42.37 tpy |
| Volatile Organic Compounds (VOC) | 12.75 tpy |
| Particulate Matter (PM ₁₀) | 6.13 tpy |
| Particulate Matter (PM _{2.5}) | 6.13 tpy |

These emissions are derived from the estimated overall emission contribution from operating limits. Exceedance of the operating limits may be considered credible evidence of the exceedance of emission limits. Compliance with the annual emission limits may be determined as stated in Conditions 1, 2, 9, 11, 12, and 13.
(9VAC5-80-1180) [8/4/2025]

16. **Visible Emission Limit** – Visible emissions from each emergency diesel engine gen-set (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) exhausts shall not exceed 5% opacity except during one 6-minute period in any one hour in which visible emissions shall not exceed 10% opacity as determined by EPA Method 9 (reference 40 CFR 60, Appendix A). This condition applies at all times except during startup, shutdown and malfunction.

During startup and shutdown, visible emissions from each emergency diesel engine gen-set shall not exceed 10% opacity except during one 6-minute period in any one hour in which visible emissions shall not exceed 20% opacity as determined by EPA Method 9 (reference 40 CFR 60, Appendix A).
(9VAC5-80-1180 and 9VAC5-50-260) [8/4/2025]

INITIAL COMPLIANCE DETERMINATION

17. **Stack Test** – Initial performance tests shall be conducted on five (5) of the twenty-six (26) emergency diesel engine gen-sets (Ref. Nos. EG2-1 through EG2-26) for NO_x (as NO₂) and CO using appropriate EPA reference methods as approved by the Regional Air Compliance Manager of the DEQ's NRO to determine compliance with the emission limits contained in Condition 13.

- a. Emissions testing of each pollutant for each selected emergency diesel engine gen-set shall consist of three one-hour test runs under load. The average of the three runs shall be reported as the short-term emission rate for that emergency diesel engine gen-set.
- b. Testing shall be performed on the exhaust stack of the emergency diesel engine gen-sets to demonstrate compliance with the NO_x and CO emission limits specified in Condition 13. Testing shall be conducted with the emergency diesel engine gen-set operating at ≥ 90 percent of its rated capacity, unless multiple load band testing is approved by DEQ;
- c. Recorded emergency diesel engine gen-set operational information shall include, but not be limited to:
 - i. Generator load/kilowatt output.
 - ii. Fuel consumption and fuel sulfur content of the diesel fuel oil.
- d. Perform testing to demonstrate compliance within 120 days after the integration operational period has commenced. The integration operational period is defined as: the period of time beginning with the first time the affected unit is started on-site and ending when the affected unit is fully integrated with the source electrical system. In no case shall the integration operational period exceed 30 days. If this deadline falls within the ozone season (May 1 through September 30) the facility shall perform testing to demonstrate compliance within 30 days after the end of the ozone season. Tests shall be conducted and reported and data reduced as set forth in 9VAC5-50-30;
- e. The details of the tests are to be arranged with the Regional Air Compliance Manager of DEQ's NRO. The permittee shall submit the test protocol to the Regional Air Compliance Manager of DEQ's NRO, at least thirty days prior to testing to ensure adequate time for DEQ approval. If the test protocol is received by the DEQ with less than thirty days for review and acceptance, DEQ approval may not be issued in a timely manner to allow for testing to take place according to the permittee's schedule;
- f. Should conditions occur which would require rescheduling the testing, the permittee shall notify the Regional Air Compliance Manager of DEQ's NRO, in writing, within seven days of the scheduled test date or as soon as the rescheduling is deemed necessary; and
- g. Two copies, one paper copy and one on removable electronic media, of the test results shall be submitted to the Regional Air Compliance Manager, DEQ's NRO within 60 days after test completion and shall conform to the test report format enclosed with this permit.

(9VAC5-50-30 and 9VAC5-80-1200) [6/1/2022]

18. **Stack Test** – Initial performance tests shall be conducted on two (2) of the emergency diesel engine gen-sets (Ref. Nos. EG4-1 through EG4-12) for NO_x (as NO₂) and CO using appropriate EPA reference methods as approved by the Regional Air Compliance Manager of the DEQ's NRO to determine compliance with the emission limits contained in Condition 13.
- a. Emissions testing of each pollutant for each selected emergency diesel engine gen-set shall consist of three one-hour test runs under load. The average of the three runs shall be reported as the short-term emission rate for that emergency diesel engine gen-set.
 - b. Testing shall be performed on the exhaust stack of the emergency diesel engine gen-sets to demonstrate compliance with the NO_x and CO emission limits specified in Condition 13. Testing shall be conducted with the emergency diesel engine gen-set operating at ≥ 90 percent of its rated capacity, unless multiple load band testing is approved by DEQ;
 - c. Recorded emergency diesel engine gen-set operational information shall include, but not be limited to:
 - i. Generator load/kilowatt output.
 - ii. Fuel consumption and fuel sulfur content of the diesel fuel oil.
 - d. Perform testing to demonstrate compliance within 120 days after the integration operational period has commenced. The integration operational period is defined as: the period of time beginning with the first time the affected unit is started on-site and ending when the affected unit is fully integrated with the source electrical system. In no case shall the integration operational period exceed 30 days. If this deadline falls within the ozone season (May 1 through September 30) the facility shall perform testing to demonstrate compliance within 30 days after the end of the ozone season. Tests shall be conducted and reported and data reduced as set forth in 9VAC5-50-30;
 - e. The details of the tests are to be arranged with the Regional Air Compliance Manager of DEQ's NRO. The permittee shall submit the test protocol to the Regional Air Compliance Manager of DEQ's NRO, at least thirty days prior to testing to ensure adequate time for DEQ approval. If the test protocol is received by the DEQ with less than thirty days for review and acceptance, DEQ approval may not be issued in a timely manner to allow for testing to take place according to the permittee's schedule;
 - f. Should conditions occur which would require rescheduling the testing, the permittee shall notify the Regional Air Compliance Manager of DEQ's NRO, in writing, within seven days of the scheduled test date or as soon as the rescheduling is deemed necessary; and

- g. Two copies, one paper copy and one on removable electronic media, of the test results shall be submitted to the Regional Air Compliance Manager, DEQ's NRO within 60 days after test completion and shall conform to the test report format enclosed with this permit.

(9VAC5-50-30 and 9VAC5-80-1200) [8/4/2025]

- 19. **Visible Emissions Evaluation** – Concurrent with the initial performance tests required in Conditions 17 and 18, Visible Emission Evaluations (VEE) in accordance with 40 CFR Part 60, Appendix A, Method 9, shall also be conducted by the permittee on the emergency diesel engine gen-sets selected for initial performance testing. The details of the tests are to be arranged with the Regional Air Compliance Manager of DEQ's NRO. The permittee shall submit a VEE protocol in conjunction with the initial stack test protocol required by Conditions 17 and 18, at least 30 days prior to testing.

- a. Should conditions prevent concurrent opacity observations, the Regional Air Compliance Manager of the DEQ's NRO shall be notified in writing, within seven (7) days, and visible emissions testing shall be rescheduled within thirty-days. Rescheduled testing shall be conducted under the same operating conditions as the initial performance tests.
- b. Two copies of the test result (one hard copy and one on electronic media) shall be submitted to the Regional Air Compliance Manager of the DEQ's NRO within sixty (60) days after test completion and shall conform to the test report format enclosed with this permit (Attachment A).

(9VAC5-50-30 and 9VAC5-80-1200) [8/4/2025]

CONTINUING COMPLIANCE DETERMINATION

- 20. **Facility Construction** – The emergency diesel engine gen-sets (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) shall be constructed so as to allow for emissions testing upon reasonable notice at any times, using appropriate methods. This includes constructing the facility/equipment such that volumetric flow rates and pollutant emission rates can be determined by applicable test methods and providing a stack or duct that is free from cyclonic flow. Sampling ports shall be provided when requested at the appropriate locations and safe sampling platforms and access shall be provided.

(9VAC5-50-30 F and 9VAC5-80-1180) [8/4/2025]

21. **Emission Testing/Visible Emissions Evaluation** – Upon request by the DEQ, the permittee shall conduct stack tests and/or VEEs of the emergency diesel engine gen-sets (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) to demonstrate compliance with the emission limits contained in this permit. The details of the tests shall be arranged with the Regional Air Compliance Manager of the DEQ's NRO.
(9VAC5-80-1200 and 9VAC5-50-30 G) [8/4/2025]

RECORDS

22. **On Site Records** – The permittee shall maintain records of emission data and operating parameters as necessary to demonstrate compliance with this permit. The content and format of such records shall be arranged with the Regional Air Compliance Manager of the DEQ's NRO. These records shall include, but are not limited to:
- a. Documentation from the manufacturer that each emergency diesel engine gen-set (Ref. Nos. 2C, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) is certified to meet the EPA Tier 2 emission standards.
 - b. Engine information including make, model, serial number, model year, maximum engine power (bhp), and engine displacement for each emergency diesel engine gen-set (Ref. Nos. 2B, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2).
 - c. A log of monitoring device observations as required by Condition 3 (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2).
 - d. The manufacturer's written operating instructions or procedures developed by the owner/operator that are approved by the engine manufacturer for each emergency diesel engine gen-set (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2).
 - e. Records, as necessary, to demonstrate compliance with the operating limitations of Condition 6; which includes but is not limited to: times, dates and reasons for operation of each diesel engine gen-set that was operating between May 1 and September 30.
 - f. To verify compliance with Condition 7, maintain records for the emergency diesel engine gen-sets (Ref. Nos. EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) of:

- i. The forecasted AQI, as determined by the AirNow website for Northern Virginia, for ozone for the days that an emergency diesel engine gen-set operated during the integration operational period;
 - ii. The measured AQI, as determined by the AirNow website for Northern Virginia, for ozone for the days that an emergency diesel engine gen-set operated during the integration operational period;
 - iii. Documentation recording any Air Alerts issued for that operating day, as determined by AirNow-EnviroFlash; and
 - iv. Details of commissioning activities, to include, but not limited to, clock hours, and duration.
- g. Monthly and annual hours of operation of each emergency diesel engine gen-set (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2), with annual hours of operation calculated monthly as the sum of each consecutive 12-month period, to verify compliance with the operational limitations specified in Condition 8.a.
- h. Annual hours of operation of each emergency diesel engine gen-set (Ref. Nos. 2C, 3A, 3B, 3C, 3D, and 3S), for purposes of scheduled maintenance checks/readiness testing, unscheduled maintenance, testing, and operational training, calculated monthly as the sum of each consecutive 12-month period, to verify compliance with the operational limitations specified in Condition 8.b.
- i. Monthly and annual hours of operation of each emergency diesel engine gen-set (Ref. Nos. EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) for purposes of scheduled maintenance checks and readiness testing (Scheduled MCRT), calculated monthly as the sum of each consecutive 12-month period, to verify compliance with the operational limitations specified in Condition 8.c.
- j. Records of the reasons for operation for each emergency diesel engine gen-set (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2), including, but not limited to, the date, cause of operation, cause of the emergency, the ISO-declared emergency notification, and the hours of operation.
- k. All fuel supplier certifications.
- l. Daily and annual fuel consumption of the emergency diesel engine gen-set (Ref. No. EG2BB), for all purposes, with the annual fuel consumption calculated daily as the sum of each consecutive 365-day period, to verify compliance with the operational limitations specified in Condition 11.a.

- m. Daily and annual fuel consumption of the combined operation of the emergency diesel engine gen-sets (Ref. Nos. EG4BB1 and EG4BB2), for all purposes, with the annual fuel consumption calculated daily as the sum of each consecutive 365-day period, to verify compliance with the operational limitations specified in Condition 11.b.
- n. Daily and annual fuel consumption for each diesel engine gen-set (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, and EG4-1 through EG4-12) by group (Group 1, Group 2, and Group 3), calculated daily as the sum of each consecutive 365-day period for the purposes of the compliance demonstration with the diesel fuel throughput limit equation in Condition 12.
- o. Daily and annual results of the computed fuel throughput equation used by the diesel engine gen-sets' (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, and EG4-1 through EG4-12) groups (Group 1, Group 2, and Group 3), calculated daily as the sum of each consecutive 365-day period for the purposes of the compliance demonstration with the diesel fuel throughput limit equation in Condition 12.
- p. Daily and annual emissions calculations for NO_x (as NO₂), CO, VOC, PM₁₀, and PM_{2.5} from the diesel engine gen-sets (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, and EG4-1 through EG4-12) for all operations, combined, to verify compliance with the annual emissions limitations in Condition 14, with annual emissions calculated daily as the sum of each consecutive 365-day period.
- q. Daily and annual emissions for NO_x (as NO₂), CO, VOC, PM₁₀, and PM_{2.5} from the diesel engine gen-sets (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) for all operations, combined, to verify compliance with the annual emissions limitations in Condition 15, with annual emissions calculated daily as the sum of each consecutive 365-day period.
- r. Results of all stack tests and VEEs.
- s. Records of scheduled maintenance checks and readiness testing (Scheduled MCRT).
- t. Records of unscheduled maintenance and operator training.
- u. Records of changes in settings that are permitted by the manufacturer of the emergency diesel engine gen-sets (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2).

Compliance for the consecutive 12-month period in the subsections above (as applicable) shall be demonstrated monthly by adding the total for the most recently completed month to the individual monthly totals for the preceding 11 months.

Compliance for the consecutive 365-day period in the subsections above (as applicable) shall be demonstrated daily by adding the total for the most recently completed day to the individual daily totals for the preceding 364 days.

These records shall be available for inspection by the DEQ and shall be current for the most recent five years.

(9VAC5-80-1180 and 9VAC5-50-50) [8/4/2025]

NOTIFICATIONS

23. **Notifications** – All correspondence concerning this permit should be submitted to the following address:

Regional Air Compliance Manager
Department of Environmental Quality
13901 Crown Court
Woodbridge, VA 22193

(9VAC5-50-50) [6/1/2022]

24. **Initial Notifications** - The permittee shall furnish written notification of items a through e below to the Regional Air Compliance Manager of the DEQ's NRO:

- a. The actual date on which construction of each emergency diesel engine gen-set (Ref. Nos. 3A, 3B, 3C, 3D, and 3S) commenced within 30 days after such date. Along with this notification, the information below shall be included:
 - i. Name and address of the permittee;
 - ii. The address of the affected source;
 - iii. Engine information, including make, model, engine family, serial number, model, year, maximum engine power and engine displacement; and
 - iv. Fuel used.
- b. The anticipated start-up date of each emergency diesel engine gen-set (Ref. Nos. 3A, 3B, 3C, 3D, and 3S) postmarked not more than 60 days nor less than 30 days prior to such date.

- c. The actual start-up date of each emergency diesel engine gen-set (Ref. Nos. 3A, 3B, 3C, 3D, and 3S) within 15 days after such date. The actual start-up date for each emergency diesel engine gen-set shall be the date on which each engine completes manufacturer's trials, but shall be no later than thirty days after the initial start-up for manufacturer's trials.
- d. The actual date on which construction of the emergency diesel engine gen-set (Ref. No. 2C) commenced, within 15 days after the date of this permit. Along with this notification, the information below shall be included:
 - i. Name and address of the permittee;
 - ii. The address of the affected source;
 - iii. Engine information, including make, model, engine family, serial number, model, year, maximum engine power and engine displacement; and
 - iv. Fuel used.
- e. The actual start-up date of the emergency diesel engine gen-set (Ref. No. 2C) within 15 days after the date of this permit.

(9VAC5-50-50 and 9VAC5-80-1180) [6/1/2022]

25. **Initial Notifications** – The permittee shall furnish written notification of the items below to the Regional Air Compliance Manager of the DEQ's NRO at the address in Condition 23.

The permittee shall submit notification(s) for each building containing the information as described below:

- a. The actual date on which installation of the emergency diesel engine gen-sets (Ref. Nos. EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) commenced in each building, within 30 days after such date. The notification must contain the following:
 - i. Name and address of the permittee;
 - ii. The building;
 - iii. Unit reference number of the initial unit installed; and
 - iv. The date installation commenced.

- b. The start and end dates of the integration operational period for each emergency diesel engine gen-set (Ref. Nos. EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) within 15 days after the last generator at each building completes its integration operational period. If a period of construction is paused or halted for ≥ 45 days, this notification shall be provided to the DEQ within 15 days after completion of the integration operational period for the most recently installed engine gen-set. The notification must contain the following:
 - i. Unit reference number;
 - ii. Engine information including make, model, engine family, serial number, model year, maximum engine power, engine displacement, fuel used;
 - iii. Installation date; and
 - iv. Integration operational period start and end dates.

For the purpose of this notification, the integration operational period is defined as the period of time beginning with the first time the affected unit is started on-site and ending when the affected unit is fully integrated with the source's electrical system.
(9VAC5-50-20) [8/4/2025]

GENERAL CONDITIONS

- 26. **Permit Invalidation** – This permit to construct the emergency diesel engine gen-sets (Ref. Nos. 1A, 1C, 1D, 1E, 1S, 2A, 2B, 2C, 2S, 3A, 3B, 3C, 3D, 3S, EG2-1 through EG2-26, EG2BB, EG4-1 through EG4-12, EG4BB1, and EG4BB2) shall become invalid, unless an extension is granted by the DEQ, if:
 - a. A program of continuous construction is not commenced within 18 months from the date of this permit, or if
 - b. A program of construction is discontinued for a period of 18 months or more, or is not completed within a reasonable time.

(9VAC5-80-1210)
- 27. **Permit Suspension/Revocation** – This permit may be suspended or revoked if the permittee:
 - a. Knowingly makes material misstatements in the permit application or any amendments to it;
 - b. Fails to comply with the conditions of this permit;

- c. Fails to comply with any emission standards applicable to a permitted emissions unit;
- d. Causes emissions from the stationary source which result in violations of, or interfere with the attainment and maintenance of, any ambient air quality standard; or
- e. Fails to operate in conformance with any applicable control strategy, including any emission standards or emissions limitations, in the State Implementation Plan in effect at the time an application for this permit is submitted.

(9VAC5-80-1210 G)

28. **Right of Entry** – The permittee shall allow authorized local, state, and federal representatives, upon the presentation of credentials:

- a. To enter upon the permittee's premises on which the facility is located or in which any records are required to be kept under the terms and conditions of this permit;
- b. To have access to and copy at reasonable times any records required to be kept under the terms and conditions of this permit or the State Air Pollution Control Board Regulations;
- c. To inspect at reasonable times any facility, equipment, or process subject to the terms and conditions of this permit or the State Air Pollution Control Board Regulations; and
- d. To sample or test at reasonable times.

For purposes of this condition, the time for inspection shall be deemed reasonable during regular business hours or whenever the facility is in operation. Nothing contained herein shall make an inspection time unreasonable during an emergency.

(9VAC5-170-130 and 9VAC5-80-1180)

29. **Maintenance/Operating Procedures** – At all times, including periods of start-up, shutdown, and malfunction, the permittee shall, to the extent practicable, maintain and operate the affected source, including associated air pollution control equipment, in a manner consistent with good air pollution control practices for minimizing emissions.

The permittee shall take the following measures in order to minimize the duration and frequency of excess emissions:

- a. Develop a maintenance schedule and maintain records of all scheduled and non-scheduled maintenance.
- b. Maintain an inventory of spare parts.

- c. Have available written operating procedures for equipment. These procedures shall be based on the manufacturer's recommendations, at a minimum.
- d. Train operators in the proper operation of all such equipment and familiarize the operators with the written operating procedures, prior to their first operation of such equipment. The permittee shall maintain records of the training provided including the names of trainees, the date of training and the nature of the training.

Records of maintenance and training shall be maintained on site for a period of five years and shall be made available to DEQ personnel upon request.
(9VAC5-50-20 E and 9VAC5-80-1180 D)

- 30. **Record of Malfunctions** – The permittee shall maintain records of the occurrence and duration of any bypass, malfunction, shutdown or failure of the facility or its associated air pollution control equipment that results in excess emissions for more than one hour. Records shall include the date, time, duration, description (emission unit, pollutant affected, cause of malfunction), corrective action, preventive measures taken and name of person generating the record.
(9VAC5-20-180 J and 9VAC5-80-1180 D)
- 31. **Notification for Facility or Control Equipment Malfunction** – The permittee shall furnish notification to the Regional Air Compliance Manager of the DEQ's NRO of malfunctions of the affected facility or related air pollution control equipment that may cause excess emissions for more than one hour. Such notification shall be made no later than four daytime business hours after the malfunction is discovered. The permittee shall provide a written statement giving all pertinent facts, including the estimated duration of the breakdown, within 14 days of discovery of the malfunction. When the condition causing the failure or malfunction has been corrected and the equipment is again in operation, the permittee shall notify the Regional Air Compliance Manager of the DEQ's NRO.
(9VAC5-20-180 C and 9VAC5-80-1180)
- 32. **Violation of Ambient Air Quality Standard** – The permittee shall, upon request of the DEQ, reduce the level of operation or shut down a facility, as necessary to avoid violating any primary ambient air quality standard and shall not return to normal operation until such time as the ambient air quality standard will not be violated.
(9VAC5-20-180 I and 9VAC5-80-1180)
- 33. **Change of Ownership** – In the case of a transfer of ownership of a stationary source, the new owner shall abide by any current minor NSR permit issued to the previous owner. The new owner shall notify the NRO of the change of ownership within 30 days of the transfer.
(9VAC5-80-1240)
- 34. **Permit Copy** – The permittee shall keep a copy of this permit on the premises of the facility to which it applies.
(9VAC5-80-1180)

SOURCE TESTING REPORT FORMAT

Report Cover

1. Plant name and location
2. Units tested at source (indicate Ref. No. used by source in permit or registration)
3. Test Dates.
4. Tester; name, address and report date

Certification

1. Signed by team leader/certified observer (include certification date)
2. Signed by responsible company official
3. *Signed by reviewer

Copy of approved test protocol

Summary

1. Reason for testing
2. Test dates
3. Identification of unit tested & the maximum rated capacity
4. *For each emission unit, a table showing:
 - a. Operating rate
 - b. Test Methods
 - c. Pollutants tested
 - d. Test results for each run and the run average
 - e. Pollutant standard or limit
5. Summarized process and control equipment data for each run and the average, as required by the test protocol
6. A statement that test was conducted in accordance with the test protocol or identification & discussion of deviations, including the likely impact on results
7. Any other important information

Source Operation

1. Description of process and control devices
2. Process and control equipment flow diagram
3. Sampling port location and dimensioned cross section Attached protocol includes: sketch of stack (elevation view) showing sampling port locations, upstream and downstream flow disturbances and their distances from ports; and a sketch of stack (plan view) showing sampling ports, ducts entering the stack and stack diameter or dimensions

Test Results

1. Detailed test results for each run
2. *Sample calculations
3. *Description of collected samples, to include audits when applicable

Appendix

1. *Raw production data
2. *Raw field data
3. *Laboratory reports
4. *Chain of custody records for lab samples
5. *Calibration procedures and results
6. Project participants and titles
7. Observers' names (industry and agency)
8. Related correspondence
9. Standard procedures

* Not applicable to visible emission evaluations