



*Commonwealth of Virginia*

***VIRGINIA DEPARTMENT OF ENVIRONMENTAL QUALITY***

NORTHERN REGIONAL OFFICE  
13901 Crown Court, Woodbridge, Virginia 22193  
(703) 583-3800 FAX (804) 698-4178  
[www.deq.virginia.gov](http://www.deq.virginia.gov)

Ann F. Jennings  
Secretary of Natural and Historic Resources

David K. Paylor  
Director  
(804) 698-4000

Thomas A. Faha  
Regional Director

October 15, 2021

Mr. Robert J. Rosenberger  
Executive Vice President, Operations  
Cashvad Ventures LLC  
1212 New York Avenue N.W.  
Suite 1000  
NW Washington, DC 20005

Location: Prince William County  
Registration No.: 74118

Dear Mr. Rosenberger:

Attached is a minor amendment to your new source review permit dated December 17, 2018 to construct and operate emergency diesel engine generator sets (gen-sets) at Cashvad Ventures LLC's data center facility, in accordance with the provisions of the Virginia State Air Pollution Control Board Regulations for the Control and Abatement of Air Pollution. This amended permit document supersedes your permit dated December 17, 2018.

In the course of evaluating the application and arriving at a final decision to approve the project, the Department of Environmental Quality (DEQ) deemed the application complete on September 17, 2021.

This permit contains legally enforceable conditions. Failure to comply may result in a Notice of Violation and/or civil charges. Please read all permit conditions carefully.

This permit approval to construct and operate shall not relieve Cashvad Ventures LLC of the responsibility to comply with all other local, state, and federal permit regulations.

The proposed emergency diesel engine gen-sets may be subject to the requirements of 40 CFR Part 60, New Source Performance Standards (NSPS) Subpart IIII – *Standards of Performance*

*for Stationary Compression Ignition Internal Combustion Engines* and 40 CFR Part 63, National Emission Standards for Hazardous Air Pollutants (MACT) Subpart ZZZZ – *National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines*. In summary, the units may be required to comply with certain federal emission standards and operating limitations. The DEQ advises you to review the referenced MACT and NSPS to ensure compliance with applicable emission and operational limitations. As the owner/operator, you are also responsible for any monitoring, notification, reporting and recordkeeping requirements of the MACT and NSPS. Notifications shall only be sent to EPA, Region III.

To review any federal rules referenced in the above paragraph or in the attached permit, the US Government Publishing Office maintains the text of these rules at [www.ecfr.gov](http://www.ecfr.gov), Title 40, Part 60 and 63.

The Board's Regulations as contained in Title 9 of the Virginia Administrative Code 5-170-200 provide that you may request a formal hearing from this case decision by filing a petition with the Board within 30 days after this case decision notice was mailed or delivered to you. Please consult the relevant regulations for additional requirements for such requests.


As provided by Rule 2A:2 of the Supreme Court of Virginia, you have 30 days from the date you actually received this permit or the date on which it was mailed to you, whichever occurred first, within which to initiate an appeal of this decision by filing a Notice of Appeal with:

David K. Paylor, Director  
Department of Environmental Quality  
P. O. Box 1105  
Richmond, VA 23218

If this permit was delivered to you by mail, three days are added to the thirty-day period in which to file an appeal. Please refer to Part Two A of the Rules of the Supreme Court of Virginia for information on the required content of the Notice of Appeal and for additional requirements governing appeals from decisions of administrative agencies.

If you have any questions concerning this permit, please contact Ms. Katie DeVoss at (703) 583-3861 or via e-mail at [katie.devoss@deq.virginia.gov](mailto:katie.devoss@deq.virginia.gov).

Sincerely,



Justin A. Wilkinson  
Regional Air Permit Manager

TAF/JAW/KD/74118 mNSR (2021-10-15)

Attachment: Permit



*Commonwealth of Virginia*

**VIRGINIA DEPARTMENT OF ENVIRONMENTAL QUALITY**

NORTHERN REGIONAL OFFICE  
13901 Crown Court, Woodbridge, Virginia 22193  
(703) 583-3800 FAX (804) 698-4178  
[www.deq.virginia.gov](http://www.deq.virginia.gov)

Ann F. Jennings  
Secretary of Natural and Historic Resources

David K. Paylor  
Director  
(804) 698-4000

Thomas A. Faha  
Regional Director

**STATIONARY SOURCE PERMIT TO CONSTRUCT AND OPERATE**

This amended permit document supersedes your permit dated December 17, 2018.

In compliance with the Federal Clean Air Act and the Commonwealth of Virginia Regulations for the Control and Abatement of Air Pollution,

Cashvad Ventures LLC  
1212 New York Avenue NW  
Suite 1000  
Washington, DC 20005  
Registration No.: 74118

is authorized to construct and operate

emergency diesel engine generator sets (gen-sets)

located at

MDC1 and MDC2 Data Centers  
10400 Harry J. Parrish Boulevard  
Manassas, VA 20110  
(Prince William County)

in accordance with the Conditions of this permit.

Approved on: December 17, 2018  
Amended on: October 15, 2021

A handwritten signature in blue ink that reads "Thomas A. Faha".

Thomas A. Faha  
Regional Director

Permit consists of 14 pages (w/o the attachment).  
Permit Conditions 1 to 28.  
Attachment A: Source Testing Report Format

## INTRODUCTION

This permit approval is based on the permit application dated February 22, 2017, and additional information received on March 8, 2017, April 25, 2017, May 1, 2017, February 6, 2018, February 13, 2018, March 1, 2018, March 8, 2018, March 13, 2018, August 27, 2018, September 13, 2018, October 17, 2018, November 2, 2018, December 3, 2018, and December 4, 2018; and application dated July 12, 2021 with additional information received on September 17, 2021.

Any changes in the permit application specifications or any existing facilities, which alter the impact of the facility on air quality, may require a permit. Failure to obtain such a permit prior to construction may result in enforcement action. In addition, this facility may be subject to additional applicable requirements not listed in this permit.

Words or terms used in this permit shall have meanings as provided in 9 VAC 5-10-20 of the State Air Pollution Control Board Regulations for the Control and Abatement of Air Pollution. The regulatory reference or authority for each condition is listed in parentheses () after each condition.

Annual requirements to fulfill legal obligations to maintain current stationary source emissions data will necessitate a prompt response by the permittee to requests by the DEQ or the Board for information to include, as appropriate: process and production data; changes in control equipment; and operating schedules. Such requests for information from the DEQ will be either in writing or by personal contact.

The availability of information submitted to the DEQ or the Board will be governed by applicable provisions of the Freedom of Information Act, §§ 2.2-3700 through 2.2-3714 of the Code of Virginia, § 10.1-1314 (addressing information provided to the Board) of the Code of Virginia, and 9 VAC 5-170-60 of the State Air Pollution Control Board Regulations. Information provided to federal officials is subject to appropriate federal law and regulations governing confidentiality of such information.

**Equipment List** – Equipment at this facility subject to permit requirements of 9VAC5-80-1100 *et seq.* consists of:

Equipment to be Constructed at MDC1 and MDC2:				
Reference No.	Equipment Description	Standby Rated Capacity	Delegated Federal Requirements	Original Permit Date
1 through 56	Fifty-six (56) Caterpillar C175-16 emergency diesel engine gen-sets	4,423 bhp 3,000 ekW (each unit)	None	December 17, 2018

The specifications included in the table above are for informational purposes only and do not form enforceable terms or conditions of the permit.

## PROCESS REQUIREMENTS

1. **Emission Controls** – Emissions from the emergency diesel engine-gen-sets shall be controlled by the following:
  - a. Nitrogen oxides (NO<sub>x</sub>) emissions from the emergency diesel engine gen-sets (Ref. Nos. 1 through 56) shall be controlled by electronic fuel injection, turbocharged engines, and charge air coolers. The permittee shall maintain documentation that demonstrates the control devices have been installed on each emergency diesel engine gen-set.
  - b. Carbon monoxide (CO) emissions, particulate matter (PM<sub>10</sub>/PM<sub>2.5</sub>) emissions, volatile organic compounds (VOC) emissions, nitrogen oxides (NO<sub>x</sub>) emissions, and visible emissions from the emergency diesel engine gen-sets (Ref. Nos. 1 through 56) shall be controlled by the use of good operating practices and performing maintenance in accordance with the manufacturer recommendations. In addition, the permittee may only change those settings that are permitted by the manufacturer and do not degrade the air emissions from the emergency diesel engine gen-sets.

(9 VAC 5-80-1180 and 9 VAC 5-50-260)

## 2. Monitoring

- a. Fuel Flow: Each emergency diesel engine gen-set (Ref. Nos. 1 through 56) shall be equipped with a device to continuously measure and record individual fuel consumption (in gallons) for each engine gen-set.
- b. Engine Operating Hours: Each emergency diesel engine gen-set (Ref. Nos. 1 through 56) shall be equipped with a non-resettable hour meter which measures the duration of time that each engine gen-set is operated.

Each monitoring device (as required in a. and b. above) shall be observed by the permittee with a frequency of not less than once each day the emergency diesel engine gen-set is operated. The permittee shall keep a log of these observations.

Each monitoring device shall be installed, maintained, calibrated (as appropriate), and operated in accordance with approved procedures which shall include, as a minimum, the manufacturer's written requirements or recommendations. The details of the monitoring device calibrations are to be arranged with the Regional Air Compliance Manager of the DEQ's Northern Regional Office (NRO).

Each monitoring device shall be provided with adequate access for inspection and shall be in operation when the engine gen-sets are operating.

(9 VAC 5-80-1180 D)

## **OPERATING/EMISSION LIMITATIONS**

3. **Operation of the Engine Gen-Sets** – The permittee shall operate and maintain each emergency diesel engine gen-set (Ref. Nos. 1 through 56) and control device according to the manufacturer's written instructions or procedures developed by the permittee that are approved by the engine manufacturer. In addition, the permittee may only change those settings that are permitted by the manufacturer and does not increase air emissions.  
(9 VAC 5-80-1180)
4. **Operating Limitations (Ozone Season)** – No emergency diesel engine gen-set (Ref. Nos. 1 through 56) shall be operated for maintenance, testing or operational training (that involves fuel combustion) between the hours of 7 a.m. to 5 p.m. any day during the ozone season of May 1 through September 30. The permittee may petition the DEQ-NRO Air Compliance Manager for exceptions to this requirement, with approvals made on a case-by-case basis.  
(9 VAC 5-80-1180)
5. **Emergency Power Generation** – The emergency diesel engine gen-sets (Ref. Nos. 1 through 56) shall only be operated in the following modes:
  - a. In situations that arise from sudden and reasonably unforeseeable events where the primary energy or power source is disrupted or disconnected due to conditions beyond the control of an owner or operator of a facility including:
    - i. A failure of the electrical grid;
    - ii. On-site disaster or equipment failure; or
    - iii. Public service emergencies such as flood, fire, natural disaster, or severe weather conditions.
  - b. For participation in an ISO-declared emergency, where an ISO emergency is:
    - i. An abnormal system condition requiring manual or automatic action to maintain system frequency, to prevent loss of firm load, equipment damage, or tripping of system elements that could adversely affect the reliability of an electric system or the safety of persons or property;
    - ii. Capacity deficiency or capacity excess conditions;
    - iii. A fuel shortage requiring departure from normal operating procedures in order to minimize the use of such scarce fuel;
    - iv. Abnormal natural events or man-made threats that would require conservative operations to posture the system in a more reliable state; or

- v. An abnormal event external to the ISO service territory that may require ISO action.
- c. For periodic maintenance, testing and operational training.

(9 VAC 5-80-1180)

6. **Operating Hours** – Each individual emergency diesel engine gen-set (Ref. Nos. 1 through 56) shall not operate more than 100 hours per year for maintenance checks and readiness testing and no more than 500 hours per year for all purposes (as provided in Condition 5) combined.

The annual limits for hours of operation shall be calculated monthly as the sum of each consecutive 12-month period. Compliance for the consecutive 12-month period shall be demonstrated monthly by adding the total for the most recently completed calendar month to the individual monthly totals for the preceding 11 months.

(9 VAC 5-80-1180)

7. **Fuel Specification** – The approved fuel for the emergency diesel engine gen-sets (Ref. Nos. 1 through 56) is ultra-low sulfur diesel fuel oil, and shall meet the specifications below:

**ULTRA LOW SULFUR DIESEL FUEL OIL:**

- a. Does not exceed the American Society for Testing and Materials (ASTM) specification, D975, for grade ultra low sulfur 2-D or grade 2-D S15, or
- b. Has a maximum sulfur content not to exceed 0.0015% by weight (15 ppm), and either a minimum cetane number of 40 or maximum aromatic content of 35 volume percent.

Exceedance of these specifications may be considered credible evidence of an exceedance of emission limits. A change in the fuel type or the fuel sulfur content may require a permit to modify and operate.

(9 VAC 5-80-1180 and 9 VAC 5-50-260)

8. **Fuel Certification** – The permittee shall obtain a certification from the fuel supplier with each shipment of diesel fuel. Each fuel supplier certification shall include the following:

- a. The name of the fuel supplier;
- b. The date on which the diesel fuel was received;
- c. The quantity of diesel fuel delivered in the shipment; and
- d. A statement that the diesel fuel:

- i. complies with the ASTM specifications for Grade No. 1-D S15 or Grade No. 2-D S15 (also known as ultra low sulfur diesel (ULSD)); or
- ii. has a sulfur content per shipment not to exceed 0.0015% by weight (15 ppm) and either a minimum cetane number of forty or maximum aromatic content of thirty-five percent by volume.

Alternatively, the permittee must obtain approval from DEQ-NRO's Regional Air Compliance Manager, if other documentation will be used to certify the diesel fuel type.

Fuel sampling and analysis, independent of that used for certification, as may be periodically required or conducted by DEQ may be used to determine compliance with the fuel specifications stipulated in Condition 7. Exceedance of these specifications may be considered credible evidence of the exceedance of emission limits.  
(9 VAC 5-80-1180)

9. **Diesel Fuel Throughput Limit** – The fifty-six (56) emergency diesel engine gen-sets (Ref. Nos. 1 through 56) combined shall:

- a. Consume no more than 579,562 gallons of diesel fuel oil per year, calculated monthly as the sum of each consecutive 12-month period (all uses) and
- b. Consume no more than 73,383 gallons of diesel fuel oil per year, calculated monthly as the sum of each consecutive 12-month period (maintenance checks and readiness testing<sup>1</sup>).

Compliance for the consecutive 12-month period shall be demonstrated monthly by adding the total for the most recently completed month to the individual monthly totals for the preceding 11-months.  
(9VAC 5-80-1180)

## EMISSION LIMITS

10. **Emission Limits (Hourly)** – Emissions from the operation of the emergency diesel engine gen-sets (Ref. Nos. 1 through 56) shall not exceed the limits specified below:

Pollutant	Caterpillar C175-16 (Ref. Nos. 1 through 56) (each unit)
Nitrogen Oxides (NO <sub>x</sub> as NO <sub>2</sub> )	58.51 lb/hr
Carbon Monoxide (CO)	14.31 lb/hr
Volatile Organic Compounds (VOC)	2.31 lb/hr
Particulate Matter (PM <sub>10</sub> )	0.80 lb/hr
Particulate Matter (PM <sub>2.5</sub> )	0.80 lb/hr

---

<sup>1</sup> This limit does not include initial (one-time) commissioning, unplanned maintenance, manufacturer recall updates and repairs.



Compliance with these pollutant emission limits shall be based on the proper operation and maintenance of the emergency diesel engine gen-sets or by testing, if required.  
(9 VAC 5-80-1180 and 9 VAC 5-50-260)

11. **Emission Limits (Annual)** – Emissions from the combined operation of the 56 emergency diesel engine gen-sets (Ref. Nos. 1 through 56) shall not exceed the limits specified below:

Pollutant	All Operations	Maintenance Checks/Readiness Testing <sup>2</sup>
Nitrogen Oxides (NO <sub>x</sub> as NO <sub>2</sub> )	79.4 tpy	10.1 tpy
Carbon Monoxide (CO)	43.5 tpy	5.6 tpy
Volatile Organic Compounds (VOC)	8.5 tpy	1.1 tpy
Particulate Matter (PM <sub>10</sub> )	2.9 tpy	0.4 tpy
Particulate Matter (PM <sub>2.5</sub> )	2.9 tpy	0.4 tpy

These emissions are derived from the estimated overall emission contribution from operating limits. Exceedance of the operating limits may be considered credible evidence of the exceedance of emission limits. Compliance with the annual pollutant emission limits may be determined as stated in Conditions 7 and 9.  
(9 VAC 5-80-1180 and 9 VAC 5-50-260)

12. **Visible Emission Limit** – Visible emissions from each emergency diesel engine gen-set (Ref. Nos. 1 through 56) exhausts shall not exceed 5% opacity except during one 6-minute period in any one hour in which visible emissions shall not exceed 10% opacity as determined by EPA Method 9 (reference 40 CFR 60, Appendix A). This condition applies at all times except during startup, shutdown and malfunction.

During startup and shutdown, visible emissions from each emergency diesel engine gen-set shall not exceed 10% opacity except during one 6-minute period in any one hour in which visible emissions shall not exceed 20% opacity as determined by EPA Method 9 (reference 40 CFR 60, Appendix A).  
(9 VAC 5-80-1180 and 9 VAC 5-50-260)

## INITIAL COMPLIANCE DETERMINATION

13. **Stack Tests** – Initial performance tests shall be conducted on one (1) of the permitted Caterpillar C175-16 emergency diesel engine gen-sets (Ref. Nos. 1 through 56) for nitrogen oxides (as NO<sub>2</sub>), and carbon monoxide (CO) to determine compliance with the respective emission limits (lb/hr) contained in Condition 10. The testing on the selected diesel engine gen-set shall be performed, reported, and demonstrate compliance within 60 days after achieving maximum power demand rate at which that unit will be operated but in no event later than 180 days after start-up of that unit. If this deadline falls within the ozone season

<sup>2</sup> These limits do not include initial (one-time) commissioning, unplanned maintenance, manufacturer recall updates and repairs.

(May 1 through September 30), the facility shall perform this testing within 30 days after the end of the ozone season. Tests shall be conducted and reported and data reduced as set forth in 9 VAC 5-50-30.

The details of the tests are to be arranged with the Air Compliance Manager of DEQ's NRO. The permittee shall submit a test protocol at least 30 days prior to testing. One copy of the test results shall be submitted to the DEQ's NRO within 30 days after test completion and shall conform to the test report format enclosed with this permit.

- a. Emissions testing of each pollutant for each selected engine gen-set shall consist of three test runs while the unit is operated at or above 90 percent of its rated capacity (standby rating). The average of the three runs shall be reported as the short-term emission rate for that engine gen-set.
- b. Recorded information shall include, but not be limited to:
  - i. Generator load/kilowatt output.
  - ii. Fuel consumption and fuel sulfur content of the diesel fuel oil.

(9 VAC 5-50-30, 9 VAC 5-80-1200 and 9 VAC 5-50-410)

14. **Stack Tests** – Initial performance tests shall be conducted on one (1) of the permitted Caterpillar C175-16 emergency diesel engine gen-sets (Ref. Nos. 1 through 56) for filterable and condensable particulate matter (PM). The testing on selected diesel engine gen-set shall be performed and reported within 60 days after achieving maximum power demand rate at which that unit will be operated but in no event later than 180 days after start-up of that unit. If this deadline falls within the ozone season (May 1 through September 30), the facility shall perform this testing within 30 days after the end of the ozone season. Tests shall be conducted and reported and data reduced as set forth in 9 VAC 5-50-30 and 9 VAC 5-60-30, and the test methods and procedures contained in each applicable section or subpart listed in 9 VAC 5-50-410 and 9 VAC 5-60-70. The details of the tests are to be arranged with the Air Compliance Manager of DEQ's NRO. The permittee shall submit a test protocol at least 30 days prior to testing and shall conform to the test report format enclosed with this permit.

***For lab testing only, not field-testing:*** Samples taken as required by this permit shall be analyzed in accordance with 1 VAC 30-46, Accreditation for Commercial Environmental Laboratories. One copy of the test results shall be submitted to the DEQ's NRO within 30 days after test completion and shall conform to the test report format enclosed with this permit.

(9 VAC 5-50-30, 9 VAC 5-80-1200, and 9 VAC 5-50-410)

15. **Visible Emissions Evaluations (VEE)** – Concurrently with the initial performance tests required by Condition 14, Visible Emission Evaluations (VEE) in accordance with 40 CFR Part 60, Appendix A-4, Method 9, shall also be conducted by the permittee on the

emergency diesel engine gen-set selected for the stack test of Condition 14. The details of the tests are to be arranged with the DEQ's NRO. The permittee shall submit a test protocol at least 30 days prior to testing. Should conditions prevent concurrent opacity observations, the DEQ-NRO shall be notified in writing, within seven days, and visible emissions testing shall be rescheduled within 30 days. Rescheduled testing shall be conducted under the same conditions (as possible) as the initial performance tests. One copy of the test result shall be submitted to the DEQ's NRO within 30 days after test completion and shall conform to the test report format enclosed with this permit.  
(9 VAC 5-50-30, 9 VAC 5-80-1200, and 9 VAC 5-50-410)

## **CONTINUING COMPLIANCE DETERMINATION**

16. **Facility Construction** – The emergency diesel engine gen-sets (Ref. Nos. 1 through 56) shall be constructed so as to allow for emissions testing upon reasonable notice at any times, using appropriate methods. This includes constructing the facility/equipment such that volumetric flow rates and pollutant emission rates can be determined by applicable test methods and providing a stack or duct that is free from cyclonic flow. Sampling ports shall be provided when requested at the appropriate locations and safe sampling platforms and access shall be provided.  
(9 VAC 5-50-30 F and 9 VAC 5-80-1180)
17. **Emission Testing/Visible Emissions Evaluation** – Upon request by the DEQ, the permittee shall conduct stack tests and/or VEEs of the emergency diesel engine gen-sets (Ref. Nos. 1 through 56) to demonstrate compliance with the emission limits contained in this permit. The details of the tests shall be arranged with the Regional Air Compliance Manager of the DEQ's NRO.  
(9 VAC 5-80-1200 and 9 VAC 5-50-30 G)

## **RECORDS**

18. **On Site Records** – The permittee shall maintain records of emission data and operating parameters as necessary to demonstrate compliance with this permit. The content and format of such records shall be arranged with the Regional Air Compliance Manager of the DEQ's NRO. These records shall include, but are not limited to:
  - a. Documentation from the manufacturer that each emergency diesel engine gen-set (Ref. Nos. 1 through 56), is certified to meet the EPA Tier 2 emission standards.
  - b. Engine information including make, model, serial number, model year, maximum engine power (bhp), and engine displacement for each emergency diesel engine gen-set (Ref. Nos. 1 through 56).
  - c. A monthly log of monitoring device observations as required by Condition 2.

- d. The manufacturer's written operating instructions or procedures developed by the owner/operator that are approved by the engine manufacturer for each emergency diesel engine gen-set (Ref. Nos. 1 through 56).
- e. Records of the reasons for operation for each emergency diesel engine gen-set (Ref. Nos. 1 through 56), including, but not limited to, the date, cause of operation, cause of the emergency, the ISO-declared emergency notification, and the hours of operation.
- f. Records, as necessary, to demonstrate compliance with the operating limitations of Condition 4; which includes but is not limited to: times, dates and reasons for operation of each diesel engine gen-set that was operating between May 1 and September 30.
- g. Monthly and annual hours of operation of each emergency diesel engine gen-set (Ref. Nos. 1 through 56), with annual hours of operation calculated monthly as the sum of each consecutive 12-month period.
- h. Monthly and annual hours of operation of each emergency diesel engine gen-set (Ref. Nos. 1 through 56), for purposes of maintenance checks/readiness testing, calculated monthly as the sum of each consecutive 12-month period.
- i. All fuel supplier certifications.
- j. Monthly and annual consumption of each emergency diesel engine gen-set (Ref. Nos. 1 through 56), with the annual fuel consumption calculated monthly as the sum of each consecutive 12-month period for all uses. This is to be recorded for both individual gen-sets and for the combined operation of all gen-sets to verify compliance with the fuel throughput limitations for all uses specified in Condition 9a.
- k. Monthly and annual fuel consumption of each emergency diesel engine gen-set (Ref. Nos. 1 through 56), with the annual fuel consumption calculated monthly as the sum of each consecutive 12-month period for maintenance checks and readiness testing. This is to be recorded for both individual gen-sets and for the combined operation of all gen-sets to verify compliance with the fuel throughput limitations for maintenance checks and readiness testing specified in Condition 9b.
- l. Monthly and annual emissions calculations for NO<sub>x</sub> (as NO<sub>2</sub>), CO, VOC, PM<sub>10</sub>, and PM<sub>2.5</sub> from the emergency diesel engine gen-sets (Ref. Nos. 1 through 56), with annual emissions, for maintenance checks and readiness testing, calculated monthly as the sum of each consecutive 12-month period, to verify compliance with the annual emission limits in Condition 11.
- m. Monthly and annual emissions calculations for NO<sub>x</sub> (as NO<sub>2</sub>), CO, VOC, PM<sub>10</sub>, and PM<sub>2.5</sub> from the emergency diesel engine gen-sets (Ref. Nos. 1 through 56), with annual emissions, for all uses, calculated monthly as the sum of each consecutive 12-

month period, to verify compliance with the annual emission limits for all uses in Condition 11.

- n. Results of all stack tests, and VEEs.
- o. Scheduled and unscheduled maintenance and operator training.
- p. Records of changes in settings that are permitted by the manufacturer of the emergency diesel engine gen-sets (Ref. Nos. 1 through 56).

Compliance for the consecutive 12-month period in the subsections above (as applicable) shall be demonstrated monthly by adding the total for the most recently completed month to the individual monthly totals for the preceding 11 months.

These records shall be available for inspection by the DEQ and shall be current for the most recent five years.  
(9 VAC 5-80-1180 and 9 VAC 5-50-50)

## NOTIFICATIONS

19. **Initial Notifications** – The permittee shall furnish written notification of the items below to the Regional Air Compliance Manager of the DEQ's NRO:

- a. The actual date on which construction of each emergency diesel engine gen-set (Ref. Nos. 1 through 56) commenced within 30 days after such date. Along with this notification, the information below shall be included:
  - i. Name and address of the permittee;
  - ii. The address of the affected source;
  - iii. Engine information, including make, model, engine family, serial number, model, year, maximum engine power and engine displacement; and
  - iv. Fuel used.
- b. The actual start-up date of each emergency diesel engine gen-set (Ref. Nos. 1 through 56) within 15 days after such date.

(9 VAC 5-50-50 and 9 VAC 5-80-1180)

## GENERAL CONDITIONS

20. **Permit Invalidation** – This permit to construct the emergency diesel engine gen-sets (Ref. Nos. 1 through 56) shall become invalid, unless an extension is granted by the DEQ, if:
- A program of continuous construction is not commenced within 18 months from the date of this permit amendment, or if
  - A program of construction is discontinued for a period of 18 months or more, or is not completed within a reasonable time.
- (9 VAC 5-80-1210)
21. **Permit Suspension/Revocation** – This permit may be suspended or revoked if the permittee:
- Knowingly makes material misstatements in the permit application or any amendments to it;
  - Fails to comply with the conditions of this permit;
  - Fails to comply with any emission standards applicable to a permitted emissions unit;
  - Causes emissions from the stationary source which result in violations of, or interfere with the attainment and maintenance of, any ambient air quality standard; or
  - Fails to operate in conformance with any applicable control strategy, including any emission standards or emissions limitations, in the State Implementation Plan in effect at the time an application for this permit is submitted.
- (9 VAC 5-80-1210 G)
22. **Right of Entry** – The permittee shall allow authorized local, state, and federal representatives, upon the presentation of credentials:
- To enter upon the permittee's premises on which the facility is located or in which any records are required to be kept under the terms and conditions of this permit;
  - To have access to and copy at reasonable times any records required to be kept under the terms and conditions of this permit or the State Air Pollution Control Board Regulations;
  - To inspect at reasonable times any facility, equipment, or process subject to the terms and conditions of this permit or the State Air Pollution Control Board Regulations; and

- d. To sample or test at reasonable times.

For purposes of this condition, the time for inspection shall be deemed reasonable during regular business hours or whenever the facility is in operation. Nothing contained herein shall make an inspection time unreasonable during an emergency.  
(9 VAC 5-170-130 and 9 VAC 5-80-1180)

23. **Maintenance/Operating Procedures** – At all times, including periods of start-up, shutdown, soot blowing, and malfunction, the permittee shall, to the extent practicable, maintain and operate the affected source, including associated air pollution control equipment, in a manner consistent with good air pollution control practices for minimizing emissions.

The permittee shall take the following measures in order to minimize the duration and frequency of excess emissions:

- a. Develop a maintenance schedule and maintain records of all scheduled and non-scheduled maintenance.
- b. Maintain an inventory of spare parts.
- c. Have available written operating procedures for equipment. These procedures shall be based on the manufacturer's recommendations, at a minimum.
- d. Train operators in the proper operation of all such equipment and familiarize the operators with the written operating procedures, prior to their first operation of such equipment. The permittee shall maintain records of the training provided including the names of trainees, the date of training and the nature of the training.

Records of maintenance and training shall be maintained on site for a period of five years and shall be made available to DEQ personnel upon request.  
(9 VAC 5-50-20 E and 9 VAC 5-80-1180 D)

24. **Record of Malfunctions** – The permittee shall maintain records of the occurrence and duration of any bypass, malfunction, shut-down or failure of the facility or its associated air pollution control equipment that results in excess emissions for more than one hour. Records shall include the date, time, duration, description (emission unit, pollutant affected, cause of malfunction), corrective action, preventive measures taken and name of person generating the record.  
(9 VAC 5-20-180 J and 9 VAC 5-80-1180 D)

25. **Notification for Facility or Control Equipment Malfunction** – The permittee shall furnish notification to the Regional Air Compliance Manager of the DEQ's NRO of malfunctions of the affected facility or related air pollution control equipment that may

cause excess emissions for more than one hour. Such notification shall be made no later than four daytime business hours after the malfunction is discovered. The permittee shall provide a written statement giving all pertinent facts, including the estimated duration of the breakdown, within 14 days of discovery of the malfunction. When the condition causing the failure or malfunction has been corrected and the equipment is again in operation, the permittee shall notify the Regional Air Compliance Manager of the DEQ's NRO.  
(9 VAC 5-20-180 C and 9 VAC 5-80-1180)

26. **Violation of Ambient Air Quality Standard** – The permittee shall, upon request of the DEQ, reduce the level of operation or shut down a facility, as necessary to avoid violating any primary ambient air quality standard and shall not return to normal operation until such time as the ambient air quality standard will not be violated.  
(9 VAC 5-20-180 I and 9 VAC 5-80-1180)
27. **Change of Ownership** – In the case of a transfer of ownership of a stationary source, the new owner shall abide by any current minor NSR permit issued to the previous owner. The new owner shall notify the NRO of the change of ownership within 30 days of the transfer.  
(9 VAC 5-80-1240)
28. **Permit Copy** – The permittee shall keep a copy of this permit on the premises of the facility to which it applies.  
(9 VAC 5-80-1180)



**Attachment A**

**Source Testing Report Format**

## **SOURCE TESTING REPORT FORMAT**

### **Report Cover**

1. Plant name and location
2. Units tested at source (indicate Ref. No. used by source in permit or registration)
3. Test Dates.
4. Tester; name, address and report date

### **Certification**

1. Signed by team leader/certified observer (include certification date)
2. Signed by responsible company official
3. \*Signed by reviewer

### **Copy of approved test protocol**

### **Summary**

1. Reason for testing
2. Test dates
3. Identification of unit tested & the maximum rated capacity
4. \*For each emission unit, a table showing:
  - a. Operating rate
  - b. Test Methods
  - c. Pollutants tested
  - d. Test results for each run and the run average
  - e. Pollutant standard or limit
5. Summarized process and control equipment data for each run and the average, as required by the test protocol
6. A statement that test was conducted in accordance with the test protocol or identification & discussion of deviations, including the likely impact on results
7. Any other important information

### **Source Operation**

1. Description of process and control devices
2. Process and control equipment flow diagram
3. Sampling port location and dimensioned cross section Attached protocol includes: sketch of stack (elevation view) showing sampling port locations, upstream and downstream flow disturbances and their distances from ports; and a sketch of stack (plan view) showing sampling ports, ducts entering the stack and stack diameter or dimensions

### **Test Results**

1. Detailed test results for each run
2. \*Sample calculations
3. \*Description of collected samples, to include audits when applicable

### **Appendix**

1. \*Raw production data
2. \*Raw field data
3. \*Laboratory reports
4. \*Chain of custody records for lab samples
5. \*Calibration procedures and results
6. Project participants and titles
7. Observers' names (industry and agency)
8. Related correspondence
9. Standard procedures

\* Not applicable to visible emission evaluations