



*Commonwealth of Virginia*

***VIRGINIA DEPARTMENT OF ENVIRONMENTAL QUALITY***

[www.deq.virginia.gov](http://www.deq.virginia.gov)

Travis A. Voyles  
Secretary of Natural and Historic Resources

Michael S. Rolband, PE, PWD, PWS Emeritus  
Director

November 6, 2024

Mr. Robb Truedinger  
Authorized Representative  
c/o Mr. Jason Bowker  
Amazon Data Services, Inc.  
13200 Woodland Park Rd.  
Herndon, VA 20171

Location: Loudoun County  
Registration No.: 74121

Dear Mr. Truedinger:

Attached is a permit to construct and operate emergency diesel engine generator sets (gen-sets) at Amazon Data Services, Inc. (IAD-90, IAD-91 and IAD-92), in accordance with the provisions of the Virginia Regulations for the Control and Abatement of Air Pollution.

In the course of evaluating the application and arriving at a final decision to approve the project, the Department of Environmental Quality (DEQ) deemed the application complete on October 18, 2024.

This permit contains legally enforceable conditions. Failure to comply may result in a Notice of Violation and/or civil charges. Please read all permit conditions carefully.

This permit approval to construct and operate shall not relieve Amazon Data Services, Inc. of the responsibility to comply with all other local, state, and federal permit regulations.

The proposed diesel fired emergency engine generator sets (engine gen-sets) may be subject to 40 CFR 63, Maximum Achievable Control Technology, (MACT) Subpart ZZZZ and 40 CFR 60, New Source Performance Standard (NSPS), Subpart IIII. Virginia has not accepted delegation of these rules. In summary, the units may be required to comply with certain federal emission standards and operating limitations. The Department of Environmental Quality (DEQ) advises you to review the referenced MACT and NSPS to ensure compliance with applicable emission and operational limitations. As the owner/operator you may be also responsible for any monitoring, notification, reporting and recordkeeping requirements of the MACT and NSPS. Notifications shall only be sent to EPA, Region III.

To review any federal rules referenced in the above paragraph or in the attached permit, the US Government Publishing Office maintains the text of these rules at [www.ecfr.gov](http://www.ecfr.gov), Title 40, Part 60 and Part 63.

The Board's Regulations as contained in Title 9 of the Virginia Administrative Code 5-170-200 provide that you may request a formal hearing from this case decision by filing a petition with the Board within 30 days after this case decision notice was mailed or delivered to you. Please consult the relevant regulations for additional requirements for such requests.


As provided by Rule 2A:2 of the Supreme Court of Virginia, you have 30 days from the date you actually received this permit or the date on which it was mailed to you, whichever occurred first, within which to initiate an appeal of this decision by filing a Notice of Appeal with:

Michael S. Rolband, Director  
Department of Environmental Quality  
P. O. Box 1105  
Richmond, VA 23218

If this permit was delivered to you by mail, three days are added to the 30-day period in which to file an appeal. Please refer to Part Two A of the Rules of the Supreme Court of Virginia for information on the required content of the Notice of Appeal and for additional requirements governing appeals from decisions of administrative agencies.

If you have any questions concerning this permit, please contact Ms. Cameron Stewart at (571) 866-6093 or via email at [cameron.stewart@deq.virginia.gov](mailto:cameron.stewart@deq.virginia.gov).

Sincerely,



Justin A. Wilkinson,  
Regional Air Permit Manager  
Virginia Department of Environmental Quality  
[justin.wilkinson@deq.virginia.gov](mailto:justin.wilkinson@deq.virginia.gov)  
Northern Regional Office  
13901 Crown Court, Woodbridge, VA 22193  
(703) 583-3800

JAW/CLS/74121 mNSR (2024-11-06)

Attachment: Permit



*Commonwealth of Virginia*

***VIRGINIA DEPARTMENT OF ENVIRONMENTAL QUALITY***

[www.deq.virginia.gov](http://www.deq.virginia.gov)

Travis A. Voyles  
Secretary of Natural and Historic Resources

Michael S. Rolband, PE, PWD, PWS Emeritus  
Director

**STATIONARY SOURCE PERMIT TO CONSTRUCT AND OPERATE**  
**This permit document supersedes your permit document dated July 27, 2017.**

In compliance with the Federal Clean Air Act and the Commonwealth of Virginia Regulations for the Control and Abatement of Air Pollution,

Amazon Data Services, Inc.  
13200 Woodland Park Rd.  
Herndon, VA 20171  
Registration No.: 74121

is authorized to construct and operate

emergency diesel engine generator sets (gen-sets)

located at

IAD-90, IAD-91 and IAD-92 Data Centers  
45900, 45930, 45950 Pathfinder Way  
Sterling, VA 20164  
(Loudoun County)

in accordance with the Conditions of this permit.

Approved on

November 6, 2024

A stylized, handwritten signature in black ink, appearing to read "Justin A. Wilkinson".

Justin A. Wilkinson  
Regional Air Permit Manager

Permit consists of 20 pages (w/o the appendix).

Permit Conditions 1 to 33.

Appendix A: Source Testing Report Format (1 page)

## **INTRODUCTION**

This permit approval is based on and combines permit terms and conditions in accordance with 9VAC5-80-1255 from the following permit approvals and the respective permit applications:

- Minor NSR Permit dated November 6, 2024 based on the permit application dated November 29, 2023 and supplemental information dated December 29, 2023, August 7, 2024, and October 18, 2024.
- Minor NSR Permit dated July 27, 2017 based on the permit application dated April 11, 2017, and supplemental information received on April 28, 2017, May 8, 2017, May 22, 2017, May 31, 2017, June 13, 2017, June 22, 2017, and July 26, 2017.

Any changes in the permit application specifications or any existing facilities which alter the impact of the facility on air quality may require a permit. Failure to obtain such a permit prior to construction may result in enforcement action. In addition, this facility may be subject to additional applicable requirements not listed in this permit.

Words or terms used in this permit shall have meanings as provided in 9VAC5-80-1110 (definitions) and 9VAC5-10-20 of the State Air Pollution Control Board Regulations for the Control and Abatement of Air Pollution. The regulatory reference or authority for each condition is listed in parentheses () after each condition. The enabling permit program, or permit programs is provided below each permit condition in the regulatory authority parenthetical as follows: 9VAC5-80-850 for Article 5, 9VAC5-80-1180 for Article 6, 9VAC5-80-1985 for Article 8, and 9VAC5-80-2050 for Article 9. The most recent effective date for a condition is listed in brackets [ ] after each regulatory reference. When identical conditions on approval for one or more emission units are combined, the listed effective date does not alter the prior effective date(s) for any such conditions as issued in a previous permit action. In accordance with 9VAC5-80-1120F, any condition not marked as state-only enforceable (SOE) is state and federally enforceable.

Annual requirements to fulfill legal obligations to maintain current stationary source emissions data will necessitate a prompt response by the permittee to requests by the Department of Environmental Quality (DEQ) or the Board for information to include, as appropriate: process and production data; changes in control equipment; and operating schedules. Such requests for information from the DEQ will either be in writing or by personal contact.

The availability of information submitted to the DEQ or the Board will be governed by applicable provisions of the Freedom of Information Act, §§ 2.2-3700 through 2.2-3714 of the Code of Virginia, § 10.1-1314 (addressing information provided to the Board) of the Code of Virginia, and 9VAC5-170-60 of the Board's Regulations. Information provided to federal officials is subject to appropriate federal law and regulations governing confidentiality of such information.

**Equipment List** – Equipment at this facility consists of the following:

<b>Equipment to be Constructed:</b>				
<b>Reference No.</b>	<b>Equipment Description</b>	<b>Rated Capacity</b>	<b>Delegated Federal Requirements</b>	<b>Original Permit Date</b>
1, 2, 5, 17 through 20, 27, 35 through 38, 48, 53, and 54	Fifteen (15) Caterpillar model 3516C emergency diesel engine gen-sets	3,634 bhp 2,500 ekW (each unit)	None	November 6, 2024

<b>Previously Permitted Equipment:</b>				
<b>Reference No.</b>	<b>Equipment Description</b>	<b>Rated Capacity</b>	<b>Delegated Federal Requirements</b>	<b>Original Permit Date</b>
3, 4, 6 through 16, 21 through 26, 28 through 34, 39 through 47, and 49 through 52	Thirty-nine (39) Caterpillar model 3516C-HD emergency diesel engine gen-sets	3,634 bhp 2,500 ekW (each unit)	None	July 27, 2017
T1 through T4	Four (4) Caterpillar model 3516C emergency diesel engine gen-sets	2,937 bhp 2,000 ekW (each unit)	None	July 27, 2017

Specifications included in the above tables are for informational purposes only and do not form enforceable terms or conditions.

## **PROCESS REQUIREMENTS**

1. **Emission Controls** – Emissions from the emergency diesel engine gen-sets shall be controlled by the following:
  - a. Nitrogen oxides (NO<sub>x</sub>) emissions from the emergency diesel engine gen-sets (Ref. Nos. 3, 4, 6 through 16, 21 through 26, 28 through 34, 39 through 47, 49 through 52, and T1 through T4) shall be controlled by electronic fuel injection and turbocharged engines. The permittee shall maintain documentation that demonstrates the control devices have been installed on each emergency diesel engine gen-set.
  - b. Nitrogen oxides (NO<sub>x</sub>) emissions from each emergency diesel engine gen-set (Ref. Nos. 1, 2, 5, 17 through 20, 27, 35 through 38, 48, 53, and 54) shall be controlled by engine design.

- c. Carbon monoxide (CO) emissions, particulate matter (PM<sub>10</sub>/PM<sub>2.5</sub>) emissions, volatile organic compounds (VOCs) emissions, and visible emissions from the emergency diesel engine gen-sets (Ref. Nos. 1 through 54 and T1 through T4) shall be controlled by the use of good operating practices and performing maintenance in accordance with the manufacturer recommendations. In addition, the permittee may only change those settings that are permitted by the manufacturer and do not degrade the air emissions from the emergency diesel engine gen-sets.

(9VAC5-80-1180 and 9VAC5-50-260) [11/6/2024]

## 2. **Monitoring**

- a. Fuel Flow: Each emergency diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4) shall be equipped with a device to continuously measure and record individual fuel consumption (in gallons) for each engine gen-set.
- b. Engine Operating Hours: Each emergency diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4) shall be equipped with a non-resettable hour meter which measures the duration of time that each engine gen-set is operated.

Each monitoring device (as required in a. and b. above) shall be observed by the permittee with a frequency of not less than once each day the emergency diesel engine gen-set is operated. The permittee shall keep a log of these observations.

Each monitoring device shall be installed, maintained, calibrated (as appropriate), and operated in accordance with approved procedures which shall include, as a minimum, the manufacturer's written requirements or recommendations. The details of the monitoring device calibrations are to be arranged with the Regional Air Compliance Manager of the DEQ's Northern Regional Office (NRO).

Each monitoring device shall be provided with adequate access for inspection and shall be in operation when the engine gen-sets are operating.  
(9VAC5-80-1180D and 9VAC5-50-20C) [11/6/2024]

## **OPERATING LIMITATIONS**

3. **Emergency Power Generation** – The emergency diesel engine gen-sets (Ref. Nos. 1 through 54 and T1 through T4) shall only be operated in the following modes:
  - a. In situations that arise from sudden and reasonably unforeseeable events where the primary energy or power source is disrupted or disconnected due to conditions beyond the control of an owner or operator of a facility including:
    - i. A failure of the electrical grid;
    - ii. On-site disaster or equipment failure; or

- iii. Public service emergencies such as flood, fire, natural disaster, or severe weather conditions.
- b. For participation in an ISO-declared emergency, where an ISO emergency is:
  - i. An abnormal system condition requiring manual or automatic action to maintain system frequency, to prevent loss of firm load, equipment damage, or tripping of system elements that could adversely affect the reliability of an electric system or the safety of persons or property;
  - ii. Capacity deficiency or capacity excess conditions;
  - iii. A fuel shortage requiring departure from normal operating procedures in order to minimize the use of such scarce fuel;
  - iv. Abnormal natural events or man-made threats that would require conservative operations to posture the system in a more reliable state; or
  - v. An abnormal event external to the ISO service territory that may require ISO action.
- c. For scheduled maintenance checks and readiness testing (Scheduled MCRT).
- d. For unscheduled maintenance, testing, and operational training.
- e. For the integration operational period, which is the period of time beginning with the first time the affected unit is started on-site and ending when the affected unit is fully integrated with the sources electrical system.

(9VAC5-80-1180) [11/6/2024]

4. **Operation of the Engine Gen-Sets** – The permittee shall operate and maintain each emergency diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4) and control device according to the manufacturer’s written instructions or procedures developed by the permittee that are approved by the engine manufacturer. In addition, the permittee may only change those settings that are permitted by the manufacturer and do not increase air emissions.

(9VAC5-80-1180) [11/6/2024]

5. **Operating Limitations (Ozone Season)** – No emergency diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4) shall be operated for scheduled maintenance checks and readiness testing (Scheduled MCRT), stack testing, or operational training (that involves fuel combustion) between the hours of 7 a.m. to 5 p.m. any day during May 1 through September 30. The permittee may petition the Regional Air Compliance Manager of DEQ’s NRO, for exceptions to this requirement, with approvals made on a case-by-case basis.

(9VAC5-80-1180) [11/6/2024]

6. **Operating Limitations (Ozone Season) – Integration Operational Period** – During the integration operational period of each emergency diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4) any operation of the unit (that involves fuel combustion) between the hours of 7 a.m. to 5 p.m. any day during the ozone season of May 1 through September 30 shall only occur if the forecast Air Quality Index (AQI) for ozone as published on the AirNow website (<https://airnow.gov>) for Northern Virginia for that day is less than or equal to 100. In the event that AirNow-EnviroFlash ([www.enviroflash.info](http://www.enviroflash.info)) issues an Air Alert for Metropolitan Washington, D.C. for a day which the forecasted AQI for ozone was less than or equal to 100, operation of each unit (which involves fuel combustion) shall be minimized to the maximum extent practical.  
(9VAC5-80-1180) [11/6/2024]

7. **Operating Hours** –

- a. Each individual emergency diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4) shall not operate more than 35 hours per year for scheduled maintenance checks and readiness testing (Scheduled MCRT, as provided in Condition 3.c.).
- b. Each individual emergency diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4) shall not operate more than 500 hours per year for all purposes (as provided in Condition 3) combined.

The annual limits for hours of operation shall be calculated monthly as the sum of each consecutive 12-month period. Compliance for the consecutive 12-month period shall be demonstrated monthly by adding the total for the most recently completed calendar month to the individual monthly totals for the preceding 11 months.

(9VAC5-80-1180) [11/6/2024]

8. **Fuel Specification** – The approved fuel for the emergency diesel engine gen-sets (Ref. Nos. 1 through 54 and T1 through T4) is diesel fuel oil. For the purposes of this permit document, diesel fuel oil is defined as ultra-low sulfur diesel fuel oil (ULSD), renewable diesel, or a blend of these fuels, and shall meet the specifications below:

**DIESEL FUEL OIL:**

- a. Does not exceed the American Society for Testing and Materials (ASTM) specification, D975, for grade ultra-low sulfur 2-D or grade 2-D S15, or,
- b. Has a maximum sulfur content not to exceed 0.0015% by weight (15 ppm), and either a minimum cetane number of 40 or maximum aromatic content of 35 volume percent.

Exceedance of these specifications may be considered credible evidence of an exceedance of emission limits. A change in the fuel type or the fuel sulfur content may require a permit to modify and operate.

(9VAC5-80-1180) [11/6/2024]



9. **Fuel Certification** – The permittee shall obtain a certification from the fuel supplier with each shipment of diesel fuel oil. Each fuel supplier certification shall include the following:

- a. The name of the fuel supplier;
- b. The date on which the diesel fuel oil was received;
- c. The quantity of diesel fuel oil delivered in the shipment;
- d. A statement that the diesel fuel oil complies with the requirements of Condition 8 (Fuel Specification).

Alternatively, the permittee shall obtain approval from the Regional Air Compliance Manager of the DEQ's NRO if other documentation will be used to certify the diesel fuel oil type.

Fuel sampling and analysis, independent of that used for certification, as may be periodically required or conducted by the DEQ, may be used to determine compliance with the fuel specifications stipulated in Condition 8.  
(9VAC5-80-1180) [11/6/2024]

10. **Diesel Fuel Throughput Limits** –

- a. The emergency diesel engine gen-sets (Ref. Nos. 1 through 54 and T1 through T4) combined shall consume no more than 684,581 gallons of diesel fuel oil per year, calculated daily as the sum of each consecutive 365-day period (all uses).
- b. The emergency diesel engine gen-sets (Ref. Nos. T1 through T4) combined shall consume no more than 8,280 gallons of diesel fuel oil per year, calculated daily as the sum of each consecutive 365-day period (all uses).

Compliance for the consecutive 365-day period shall be demonstrated daily by adding the total for the most recently completed calendar day to the individual daily totals for the preceding 364 days.  
(9VAC5-80-1180) [11/6/2024]

## **EMISSION LIMITS**

11. **Emission Limits (Hourly)** – Emissions from the operation of each emergency diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4) shall not exceed the limits specified below:

<b>Pollutant</b>	<b>Ref. Nos. 1 through 54</b>	<b>Ref. Nos. T1 through T4</b>
Nitrogen Oxides (NO <sub>x</sub> as NO <sub>2</sub> )	48.06 lbs/hr	38.85 lbs/hr
Carbon Monoxide (CO)	6.09 lbs/hr	3.95 lbs/hr
Volatile Organic Compounds (VOC)	1.21 lbs/hr	1.14 lbs/hr
Particulate Matter (PM <sub>10</sub> )	0.40 lbs/hr	0.57 lbs/hr
Particulate Matter (PM <sub>2.5</sub> )	0.40 lbs/hr	0.57 lbs/hr

Compliance with these emission limits shall be based on the proper operation and maintenance of the emergency diesel engine gen-sets or by testing, if required.  
(9VAC5-80-1180 and 9VAC5-50-260) [11/6/2024]

12. **Emission Limits (Annual)** – Emissions from the operation of the emergency diesel engine gen-sets (Ref. Nos. 1 through 54 and T1 through T4) shall not exceed the limits specified below:

<b>Pollutant</b>	<b>Ref. Nos. 1 through 54 and T1 through T4</b>
Nitrogen Oxides (NO <sub>x</sub> as NO <sub>2</sub> )	96.03 tpy
Carbon Monoxide (CO)	51.71 tpy
Volatile Organic Compounds (VOC)	10.83 tpy
Particulate Matter (PM <sub>10</sub> )	3.55 tpy
Particulate Matter (PM <sub>2.5</sub> )	3.55 tpy

These emissions are derived from the estimated overall emission contribution from operating limits. Exceedance of the operating limits may be considered credible evidence of the exceedance of emission limits. Compliance with the annual emission limits may be determined as stated in Conditions 1, 10, and 11.  
(9VAC5-80-1180) [11/6/2024]

13. **Visible Emission Limit** – Visible emissions from each emergency diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4) shall not exceed 5% opacity except during one six-minute period in any one hour in which visible emissions shall not exceed 10% opacity as determined by the EPA Method 9 (reference 40 CFR 60, Appendix A). This condition applies at all times except during startup, shutdown and malfunction.

During startup and shutdown, visible emissions from each engine gen-set (Ref. Nos. 1 through 54 and T1 through T4) shall not exceed 10% opacity except during one six-minute

period in any one-hour in which visible emissions shall not exceed 20% opacity as determined by EPA Method 9 (reference 40 CFR 60, Appendix A).  
(9VAC5-80-1180) [11/6/2024]

#### **INITIAL COMPLIANCE DETERMINATION**

14. **Stack Test (ULSD)** – Initial performance tests shall be conducted on three (3) emergency diesel engine gen-sets (Ref. Nos. 1, 2, 5, 17 through 20, 27, 35 through 38, 48, 53, and 54) while utilizing ULSD for NO<sub>x</sub> (as NO<sub>2</sub>) and CO using appropriate EPA reference methods as approved by the Regional Air Compliance Manager of the DEQ's NRO to determine compliance with the emission limits contained in Condition 11.
- a. Emissions testing of each pollutant for each selected emergency diesel engine gen-set shall consist of three (3) one-hour test runs under load. The average of the three (3) runs shall be reported as the short-term emission rate for that emergency diesel engine gen-set.
  - b. Testing shall be performed on the exhaust stack of the emergency diesel engine gen-sets to demonstrate compliance with the NO<sub>x</sub> and CO emission limits specified in Condition 11. Testing shall be conducted with the emergency diesel engine gen-set operating at  $\geq 90$  percent of its rated capacity, unless multiple load band testing is approved by DEQ;
  - c. Recorded emergency diesel engine gen-set operational information shall include, but not be limited to:
    - i. Generator load/kilowatt output.
    - ii. Fuel consumption and fuel sulfur content of the diesel fuel oil.
  - d. Perform testing to demonstrate compliance within 120 days after the integration operational period has commenced. The integration operational period is defined as: the period of time beginning with the first time the affected unit is started on-site and ending when the affected unit is fully integrated with the source electrical system. If this deadline falls within the ozone season (May 1 through September 30) the facility shall perform testing to demonstrate compliance within 30 days after the end of the ozone season. Tests shall be conducted and reported and data reduced as set forth in 9VAC5-50-30;
  - e. The details of the tests are to be arranged with the Regional Air Compliance Manager of DEQ's NRO. The permittee shall submit the test protocol to the Regional Air Compliance Manager of DEQ's NRO, at least 30 days prior to testing to ensure adequate time for DEQ approval. If the test protocol is received by the DEQ with less than 30 days for review and acceptance, DEQ approval may not be issued in a timely manner to allow for testing to take place according to the permittee's schedule;

- f. Should conditions occur which would require rescheduling the testing, the permittee shall notify the Regional Air Compliance Manager of DEQ's NRO, in writing, within seven (7) days of the scheduled test date or as soon as the rescheduling is deemed necessary; and
- g. Two (2) copies (one (1) paper copy and one (1) electronic copy) of the test results shall be submitted to the Regional Air Compliance Manager, DEQ's NRO within 60 days after test completion and shall conform to the test report format enclosed with this permit.

(9VAC5-50-30 and 9VAC5-80-1200) [11/6/2024]

**15. Stack Test (Renewable Diesel)** – Performance tests shall be conducted on two (2) emergency diesel engine gen-sets (Ref. Nos. 1 through 54) while utilizing renewable diesel or a blend of renewable diesel and ULSD for NO<sub>x</sub> (as NO<sub>2</sub>) and CO using appropriate EPA reference methods as approved by the Regional Air Compliance Manager of the DEQ's NRO to determine compliance with the emission limits contained in Condition 11.

- a. Emissions testing of each pollutant for each selected emergency diesel engine gen-set shall consist of three (3) one-hour test runs under load. The average of the three (3) runs shall be reported as the short-term emission rate for that emergency diesel engine gen-set.
- a. Testing shall be performed on the exhaust stack of the emergency diesel engine gen-sets to demonstrate compliance with the NO<sub>x</sub> and CO emission limits specified in Condition 11. Testing shall be conducted with the emergency diesel engine gen-set operating at  $\geq 90$  percent of its rated capacity, unless multiple load band testing is approved by DEQ;
- b. Recorded emergency diesel engine gen-set operational information shall include, but not be limited to:
  - i. Generator load/kilowatt output.
  - ii. Fuel consumption and fuel sulfur content of the diesel fuel oil.
- c. For any emergency engine gen-set that has not commenced the integration operational period upon receipt of the first shipment of renewable diesel or a blend of renewable diesel and ULSD utilized by the units: Perform testing to demonstrate compliance within 120 days after the integration operational period has commenced. If this deadline falls within the ozone season (May 1 through September 30), the facility shall perform testing to demonstrate compliance within 30 days after the end of the ozone season. Tests shall be conducted and reported and data reduced as set forth in 9VAC5-50-30;

- d. For any emergency engine gen-set that has commenced the integration operational period upon receipt of the first shipment of renewable diesel or a blend of renewable diesel and ULSD utilized by the units: Perform testing to demonstrate compliance within 120 days of the renewable diesel fuel or a blend of renewable diesel and ULSD first utilized by the affected units. The permittee may petition the DEQ's NRO Air Compliance Manager for an extension to this deadline, with approvals made on a case-by-case basis. If the applicable deadline falls within the ozone season (May 1 through September 30), the facility shall perform testing to demonstrate compliance within 30 days after the end of the ozone season. Tests shall be conducted and reported and data reduced as set forth in 9VAC5-50-30;
- e. The details of the tests are to be arranged with the Regional Air Compliance Manager of DEQ's NRO. The permittee shall submit the test protocol to the Regional Air Compliance Manager of DEQ's NRO, at least 30 days prior to testing to ensure adequate time for DEQ approval. If the test protocol is received by the DEQ with less than 30 days for review and acceptance, DEQ approval may not be issued in a timely manner to allow for testing to take place according to the permittee's schedule;
- f. Should conditions occur which would require rescheduling the testing, the permittee shall notify the Regional Air Compliance Manager of DEQ's NRO, in writing, within seven (7) days of the scheduled test date or as soon as the rescheduling is deemed necessary; and
- g. Two (2) copies (one (1) paper copy and one (1) electronic copy) of the test results shall be submitted to the Regional Air Compliance Manager, DEQ's NRO within 60 days after test completion and shall conform to the test report format enclosed with this permit.

(9VAC5-50-30 and 9VAC5-80-1200) [11/6/2024]

**16. Visible Emissions Evaluation** – Concurrent with the initial performance tests required in Condition 14 and 15, Visible Emission Evaluations (VEE) in accordance with 40 CFR Part 60, Appendix A, Method 9, shall also be conducted by the permittee on the emergency diesel engine gen-sets selected for initial performance testing. The details of the tests are to be arranged with the Regional Air Compliance Manager of DEQ's NRO. The permittee shall submit a VEE protocol in conjunction with the initial stack test protocol required by Condition 14 and 15, at least 30 days prior to testing.

- a. Should conditions prevent concurrent opacity observations, the Regional Air Compliance Manager of the DEQ's NRO shall be notified in writing, within seven (7) days, and visible emissions testing shall be rescheduled within thirty-days. Rescheduled testing shall be conducted under the same operating conditions as the initial performance tests.
- b. Two (2) copies of the test result (one (1) hard copy and one (1) electronic copy) shall be submitted to the Regional Air Compliance Manager of the DEQ's NRO within 60

days after test completion and shall conform to the test report format enclosed with this permit (Attachment A).

(9VAC5-50-30 and 9VAC5-80-1200) [11/6/2024]

## **CONTINUING COMPLIANCE DETERMINATION**

### **17. Facility Construction –**

- a. The emergency diesel engine gen-sets (Ref. Nos. 3, 4, 6 through 16, 21 through 26, 28 through 34, 39 through 47, 49 through 52, and T1 through T4) shall be constructed so as to allow for emissions testing upon reasonable notice, using appropriate methods. Sampling ports shall be provided when requested at the appropriate locations in accordance with EPA Reference Method 1 (reference 40 CFR Part 60, Appendix A). In addition, safe sampling platforms and access shall be provided.
- b. The emergency diesel engine gen-sets (Ref. Nos. 1, 2, 5, 17 through 20, 27, 35 through 38, 48, 53, and 54) shall be constructed so as to allow for emissions testing upon reasonable notice at any times, using appropriate methods. This includes constructing the facility/equipment such that volumetric flow rates and pollutant emission rates can be determined by applicable test methods and providing a stack or duct that is free from cyclonic flow. Sampling ports shall be provided when requested at the appropriate locations and safe sampling platforms and access shall be provided.

(9VAC5-50-30F and 9VAC5-80-1180) [11/6/2024]

- 18. Emission Testing/Visible Emissions Evaluation** – Upon request by the DEQ, the permittee shall conduct stack tests and/or visible emission evaluations of the emergency diesel engine gen-sets (Ref. Nos. 1 through 54 and T1 through T4) to demonstrate compliance with the emission limits contained in this permit. The details of the tests shall be arranged with the Regional Air Compliance Manager of the DEQ's NRO.

(9VAC5-80-1200 and 9VAC5-50-30 G) [11/6/2024]

## **RECORDS**

- 19. On Site Records** – The permittee shall maintain records of emission data and operating parameters as necessary to demonstrate compliance with this permit. The content and format of such records shall be arranged with the Regional Air Compliance Manager of the DEQ's NRO. These records shall include, but are not limited to:

- a. A monthly log of the monitoring device observations as required by Condition 2.
- b. Monthly and annual hours of operation (all purposes) of each emergency diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4), calculated monthly as the sum of each consecutive 12-month period.

- c. Monthly and annual hours of operation of each emergency diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4) for purposes of scheduled maintenance checks and readiness testing (Scheduled MCRT), calculated monthly as the sum of each consecutive 12-month period to demonstrate compliance with Condition 7.a.
- d. Daily and annual fuel consumption of each emergency diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4), for all purposes, with the annual fuel consumption calculated daily as the sum of each consecutive 365-day period.
- e. Daily and annual fuel consumption for the combined operation of the emergency diesel engine gen-sets (Ref. Nos. 1 through 54 and T1 through T4), calculated daily as the sum of each consecutive 365-day period, to verify compliance with the fuel throughput limitations specified in Condition 10.a.
- f. Daily and annual fuel consumption for the combined operation of the emergency diesel engine gen-sets (Ref. Nos. T1 through T4), calculated daily as the sum of each consecutive 365-day period, to verify compliance with the fuel throughput limitations specified in Condition 10.b.
- g. Daily and annual emissions calculations for NO<sub>x</sub> (as NO<sub>2</sub>), CO, VOC, PM<sub>10</sub>, and PM<sub>2.5</sub> from the emergency diesel engine gen-sets (Ref. Nos. 1 through 54 and T1 through T4), with annual emissions, calculated daily, as the sum of each consecutive 365-day period, to verify compliance with the annual emission limits in Condition 12.
- h. All fuel supplier certifications.
- i. Results of all stack tests and visible emission evaluations.
- j. Records of scheduled maintenance checks and readiness testing (Scheduled MCRT).
- k. Records of unscheduled maintenance and operator training.
- l. Records as required by Condition 28.
- m. Records of the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer for each emergency diesel engine gen-set.
- n. Records of changes in settings that are permitted by the manufacturer of the emergency diesel engine gen-sets.
- o. For emergency diesel engine gen-sets (Ref. Nos. 1 through 54 and T1 through T4), maintain documentation from the manufacturer that the emergency diesel engine gen-sets are certified to meet the EPA's Tier 2 emission standards.

- p. Engine information including make, model, serial number, model year, maximum engine power (bhp), and engine displacement for each emergency diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4).
- q. Records of the reasons for operation for each emergency diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4), including, but not limited to, the date, cause of operation, cause of the emergency, the ISO-declared emergency notification, and the hours of operation.
- r. Records, as necessary, to demonstrate compliance with the operating limitations of Condition 5; which includes but is not limited to: times, dates and reasons for operation of each diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4) that was operating between May 1 and September 30.
- s. To verify compliance with Condition 6, maintain records of:
  - i. The forecasted AQI, as determined by the AirNow website for Northern Virginia, for ozone for the days that an emergency diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4) operated during the integration operational period;
  - ii. The measured AQI, as determined by the AirNow website for Northern Virginia, for ozone for the days that an emergency diesel engine gen-set (Ref. Nos. 1 through 54 and T1 through T4) operated during the integration operational period;
  - iii. Documentation recording any Air Alerts issued for that operating day, as determined by AirNow-EnviroFlash; and
  - iv. Details of commissioning activities, to include, but not limited to, clock hours, and duration.

Compliance for the consecutive 12-month period in subsections above (as applicable) shall be demonstrated monthly by adding the total for the most recently completed month to the individual monthly totals for the preceding 11 months.

Compliance for the consecutive 365-day period in the subsections above (as applicable) shall be demonstrated daily by adding the total for the most recently completed day to the individual daily totals for the preceding 364 days.

These records shall be available for inspection by the DEQ and shall be current for the most recent five years, unless otherwise noted.  
(9VAC5-80-1180 and 9VAC5-50-50) [11/6/2024]

## **NOTIFICATIONS**

20. **Initial Notifications** – The permittee shall furnish written notification of the items below to the Regional Air Compliance Manager of the DEQ's NRO at the following address:



Regional Air Compliance Manager  
Department of Environmental Quality  
13901 Crown Court  
Woodbridge, VA 22193

The permittee shall submit notification(s) for each building containing the information as described below:

- a. The actual date on which installation of the emergency diesel engine gen-sets (Ref. Nos. 1, 2, 5, 17 through 20, 27, 35 through 38, 48, 53, and 54) commenced in each building, within 30 days after such date. The notification must contain the following:
  - i. Name and address of the permittee;
  - ii. The building;
  - iii. Unit reference number of the initial unit installed; and
  - iv. The date installation commenced.
- b. The start and end dates of the integration operational period for each emergency diesel engine gen-set (Ref. Nos. 1, 2, 5, 17 through 20, 27, 35 through 38, 48, 53, and 54) within 15 days after the last engine gen-set at each building completes its integration operational period. If a period of construction is paused or halted for  $\geq 45$  days, this notification shall be provided to the DEQ within 15 days after completion of the integration operational period for the most recently installed engine gen-set. The notification must contain the following:
  - i. Unit reference number;
  - ii. Engine information including make, model, engine family, serial number, model year, maximum engine power, engine displacement, fuel used;
  - iii. Installation date; and
  - iv. Integration operational period start and end dates.

For the purpose of this notification, the integration operational period is defined as the period of time beginning with the first time the affected unit is started on-site and ending when the affected unit is fully integrated with the source's electrical system.  
(9VAC5-80-1180 and 9VAC5-50-50) [11/6/2024]

21. **Initial Notifications** – The permittee shall furnish written notification of the items below to the Air Compliance Manager of the DEQ’s NRO at the following address:

Regional Air Compliance Manager  
Department of Environmental Quality  
13901 Crown Court  
Woodbridge, VA 22193

- a. The actual date on which construction of the emergency diesel engine gen-sets (Ref. Nos. 3, 4, 6 through 16, 21 through 26, 28 through 34, 39 through 47, 49 through 52, and T1 through T4) commenced within 30 days after such date. The notification must contain the following:
  - i. Name and address of the permittee,
  - ii. The address of the affected source,
  - iii. Engine information including make, model, engine family, serial number, model year, maximum engine power and engine displacement.
  - iv. Fuel used.
- b. The anticipated date of the manufacturer’s trials of the emergency diesel engine gen-sets (Ref. Nos. 3, 4, 6 through 16, 21 through 26, 28 through 34, 39 through 47, and 49 through 52) postmarked not more than 30 days nor less than 15 days prior to such date.
- c. The actual date on which the manufacturer’s trials of the emergency diesel engine gen-sets (Ref. Nos. 3, 4, 6 through 16, 21 through 26, 28 through 34, 39 through 47, and 49 through 52) occurs within 15 days after such date.
- d. The anticipated start-up date of the emergency diesel engine gen-sets (Ref. Nos. 3, 4, 6 through 16, 21 through 26, 28 through 34, 39 through 47, and 49 through 52) postmarked not more than 60 days nor less than 30 days prior to such date.
- e. The actual start-up date of the emergency diesel engine gen-sets (Ref. Nos. 3, 4, 6 through 16, 21 through 26, 28 through 34, 39 through 47, and 49 through 52) within 15 days after such date. The actual start-up date shall be the date on which each engine completes manufacturer’s trials, but shall be no later than 30 days after start-up for manufacturer’s trials.

(9VAC5-50-50 and 9VAC5-80-1180) [11/6/2024]

22. **Renewable Diesel Notification** – Upon receipt of the first shipment of renewable diesel or a blend of renewable diesel and ULSD, the permittee shall furnish written notification of the items below to the Air Compliance Manager of the DEQ's NRO at the following address:

Regional Air Compliance Manager  
Department of Environmental Quality  
13901 Crown Court  
Woodbridge, VA 22193

- a. The actual date on which the shipment was received within fifteen (15) days after such date. The notification must include the following:
  - i. Name and address of the permittee;
  - ii. The address of the affected source;
  - iii. Emergency engine gen-sets (with reference numbers) utilizing the fuel in the shipment; and
  - iv. Fuel certification (as provided in Condition 9).

(9VAC5-80-1180) [11/6/2024]

**SPECIAL CONDITIONS - TRANSITORY ENGINE GEN-SETS**

23. **Operation of the Transitory Engine Gen-Sets** – The facility shall only operate the transitory emergency diesel engine gen-sets (Ref. Nos. T1 through T4) in support of the facility such as serving as back up during construction, commissioning, and maintenance of engine gen-sets (Ref. Nos. 1 through 54).

(9 VAC 5-80-1180) [11/6/2024]

24. **Notifications** – The permittee shall furnish the following written notifications to DEQ's NRO Air Compliance Manager of:

- a. The actual date and reason for each occurrence that each transitory emergency diesel engine gen-set (Ref. Nos. T1 through T4) was placed into service within 15 days after such date. The notification must include the following:
  - i. Name and address of the permittee;
  - ii. The address of the affected source;
  - iii. Engine information including make, model, engine family, serial number, model year, maximum engine power and engine displacement;
  - iv. Fuel used; and

- v. Hours operated.
- b. The actual date of the removal of each transitory emergency diesel engine gen-set (Ref. Nos. T1 through T4) within 15 days after such date.

(9VAC5-80-1180) [11/6/2024]

### **GENERAL CONDITIONS**

25. **Permit Invalidation** – This permit to construct the emergency diesel engine gen-sets (Ref. Nos. 1 through 54) shall become invalid, unless an extension is granted by the DEQ, if:

- a. A program of continuous construction or modification is not commenced within 18 months from the “Original Permit Date” specified in the equipment list in the introduction section of this permit.
- b. A program of construction is discontinued for a period of 18 months or more, or is not completed within a reasonable time.

(9VAC5-80-1210)

26. **Permit Suspension/Revocation** – The Board may suspend or revoke any permit if the permittee:

- a. Knowingly makes material misstatements in the permit application or any amendments to it;
- b. Fails to comply with the terms or conditions of this permit;
- c. Fails to comply with any emission standards applicable to a permitted emissions unit;
- d. Causes emissions from the stationary source which result in violations of, or interfere with the attainment and maintenance of, any ambient air quality standard; or fails to operate in conformance with any applicable control strategy, including any emission standards or emission limitations, in the implementation plan in effect at the time that an application is submitted; or
- e. Fails to comply with the applicable provisions of 9VAC5-80-1100 *et seq.*

(9VAC5-80-1210F and 9VAC5-80-1210G)

27. **Right of Entry** – The permittee shall allow authorized local, state, and federal representatives, upon the presentation of credentials:

- a. To enter upon the permittee's premises on which the facility is located or in which any records are required to be kept under the terms and conditions of this permit;
- b. To have access to and copy at reasonable times any records required to be kept under the terms and conditions of this permit or the State Air Pollution Control Board Regulations;
- c. To inspect at reasonable times any facility, equipment, or process subject to the terms and conditions of this permit or the State Air Pollution Control Board Regulations; and
- d. To sample or test at reasonable times.

For purposes of this condition, the time for inspection shall be deemed reasonable during regular business hours or whenever the facility is in operation. Nothing contained herein shall make an inspection time unreasonable during an emergency.  
(9VAC5-170-130 and 9VAC5-80-1180)

28. **Maintenance/Operating Procedures** – At all times, including periods of start-up, shutdown, and malfunction, the permittee shall, to the extent practicable, maintain and operate the affected source, including associated air pollution control equipment, in a manner consistent with good air pollution control practices for minimizing emissions.

The permittee shall take measures in order to minimize the duration and frequency of excess emissions, including the following:

- a. Develop a maintenance schedule and maintain records of all scheduled and non-scheduled maintenance.
- b. Maintain an inventory of spare parts.
- c. Have available written operating procedures for equipment. These procedures shall be based on the manufacturer's recommendations, at a minimum.
- d. Train operators in the proper operation of all such equipment and familiarize the operators with the written operating procedures, prior to their first operation of such equipment. The permittee shall maintain records of the training provided including the names of trainees, the date of training and the nature of the training.

Records of maintenance shall be maintained on site for a period of five years and shall be made available to DEQ personnel upon request.  
(9VAC5-50-20E and 9VAC5-80-1180D)

29. **Record of Malfunctions** – The permittee shall maintain records of the occurrence and duration of any bypass, malfunction, shutdown or failure of the facility or its associated air pollution control equipment that results in excess emissions for more than one hour. Records shall include the date, time, duration, description (emission unit, pollutant affected, cause), corrective action, preventive measures taken and name of person generating the record.  
(9VAC5-20-180J and 9VAC5-80-1180D)
30. **Notification for Facility or Control Equipment Malfunction** – The permittee shall furnish notification to the Regional Air Compliance Manager of the DEQ's NRO of malfunctions of the affected facility or related air pollution control equipment that may cause excess emissions for more than one hour. Such notification shall be made no later than four daytime business hours after the malfunction is discovered. The permittee shall provide a written statement giving all pertinent facts, including the estimated duration of the breakdown, within two weeks of discovery of the malfunction. When the condition causing the failure or malfunction has been corrected and the equipment is again in operation, the permittee shall notify the Air Compliance Manager, the DEQ's NRO.  
(9VAC5-20-180C and 9VAC5-80-1180)
31. **Violation of Ambient Air Quality Standard** – The permittee shall, upon request of the DEQ, reduce the level of operation or shut down a facility, as necessary to avoid violating any primary ambient air quality standard and shall not return to normal operation until such time as the ambient air quality standard will not be violated.  
(9VAC5-20-180I and 9VAC5-80-1180)
32. **Change of Ownership** – In the case of a transfer of ownership of a stationary source, the new owner shall abide by any current permit issued to the previous owner. The new owner shall notify the Regional Air Compliance Manager of the DEQ's NRO of the change of ownership within 30 days of the transfer.  
(9VAC5-80-1240)
33. **Permit Copy** – The permittee shall keep a copy of this permit on the premises of the facility to which it applies.  
(9VAC5-80-1180)

## **Appendix A**

### **Source Testing Report Format**

## SOURCE TESTING REPORT FORMAT

### Report Cover

1. Plant name and location
2. Units tested at source (indicate Ref. No. used by source in permit or registration)
3. Test Dates.
4. Tester; name, address and report date

### Certification

1. Signed by team leader/certified observer (include certification date)
2. Signed by responsible company official
3. \*Signed by reviewer

### Copy of approved test protocol

### Summary

1. Reason for testing
2. Test dates
3. Identification of unit tested & the maximum rated capacity
4. \*For each emission unit, a table showing:
  - a. Operating rate
  - b. Test Methods
  - c. Pollutants tested
  - d. Test results for each run and the run average
  - e. Pollutant standard or limit
5. Summarized process and control equipment data for each run and the average, as required by the test protocol
6. A statement that test was conducted in accordance with the test protocol or identification & discussion of deviations, including the likely impact on results
7. Any other important information

### Source Operation

1. Description of process and control devices
2. Process and control equipment flow diagram
3. Sampling port location and dimensioned cross section Attached protocol includes: sketch of stack (elevation view) showing sampling port locations, upstream and downstream flow disturbances and their distances from ports; and a sketch of stack (plan view) showing sampling ports, ducts entering the stack and stack diameter or dimensions

### Test Results

1. Detailed test results for each run
2. \*Sample calculations
3. \*Description of collected samples, to include audits when applicable

### Appendix

1. \*Raw production data
2. \*Raw field data
3. \*Laboratory reports
4. \*Chain of custody records for lab samples
5. \*Calibration procedures and results
6. Project participants and titles
7. Observers' names (industry and agency)
8. Related correspondence
9. Standard procedures

---

\* Not applicable to visible emission evaluations