



STANDARDS & SPECIFICATIONS SITE INSPECTION REPORT LEVEL 1 (FIELD REPORT)

Project Name:	Mountain Valley Pipeline	S&S Program:	Mountain Valley Pipeline (SS027)
Inspector:	Marshall Willis	Inspection Date:	Tuesday, May 6, 2025
Project Contact:	Cory Chalmers Brian Clauto	Project Contact Email:	cory.chalmers@eqt.com brian.clauto@eqt.com
Spread I: Pittsylvania County	STA 15647+03 – 15693+89 MVP-PI-336.01	Site Conditions:	Dry

ACTIVE STAGE OF CONSTRUCTION: (Check all that apply)

- ☐ Tree Felling ☐ Clearing/Grubbing ☐ Rough Grading ☐ Trenching ☐ Stringing/Welding
- ☐ Lowering/Backfilling ☐ Final Grading ☐ Temp. Stabilization ☒ Perm. Stabilization ☒ Dormant

- | | Yes | No | N/A |
|--|-------------------------------------|-------------------------------------|--------------------------|
| 1. Are controls installed and implemented in accordance with the approved erosion and sediment control plan and stormwater management plans? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2. Are all control measures properly maintained in effective operating condition in accordance with good engineering practices and, where applicable, manufacturer specifications? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 3. Areas of offsite sediment deposition observed? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

Comments: Inspected the following resources: S-Q4, W-Q2, S-Q3, S-Q2 and W-Q1.

Routine Maintenance:

- STA 15658+50 to STA 15662+00: Restabilize denuded permanent waterbars.
- STA 15665+00: Restabilize denuded permanent waterbar.
- STA 15682+00 to STA 15688+00: Restabilize denuded permanent waterbars.
- STA 15691+00 to STA 15693 00: Restabilize denuded areas.

Ineffective Controls:

- N/A

Corrective Action: Maintain and install all controls per the approved S&S.

Deadline: Within 72-Hour of Notification

The recommended corrective action deadline date applies to all conditions noted on this report unless otherwise noted. If listed condition(s) currently constitute non-compliance and/or corrective actions are not completed by the deadline, other enforcement actions may be issued to the entity responsible for ensuring compliance on the above project.

Inspector Signature: 

Date: Tuesday, May 6, 2025

STANDARDS & SPECIFICATIONS

SITE INSPECTION REPORT

LEVEL 1 (FIELD REPORT)

FIELD INSPECTION PHOTO LOG

Fig. 1

STA 15658+50 to 15662+00: Restabilize perm. WBs.



Fig. 2

STA 15665+00: Restabilize perm. WB



Fig. 3

STA 15682+00 to 15688+00: Restabilize perm. WBs.



Fig. 4

STA 15691+00 to 15693+00: Restabilize denuded areas.

